

# NSW Environment Protection Authority Review of Coal Fired Power Stations Air Emissions and Monitoring

Attachment E:

NPI Emission Estimation Methodology

Table 1 – Summary of Emission Estimation Techniques applied by NSW Power Stations.

General Emission Estimation Methodology – approved method <b>except as noted in red font.</b>								
Power Station	Total solid particles (TSP)	PM <sub>10</sub>	PM <sub>2.5</sub>	Fluoride	NO <sub>x</sub>	SO <sub>2</sub>	Metals/Others	
							Direct Measure	NPI EF
<b>Bayswater 2015/16 2014/15</b>	DM - Calc_FGV <sup>1</sup> x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS NOx ppm used for all units)	DM - Calc_FGV x CEMS <sup>2</sup> monthly weighted av (Unit 1 CEMS SO2 ppm used for all units)	As, Be, Cd, Co, Cu, Pb, - Calc_FGV x stack test conc.	All others
<b>Bayswater 2013/14</b>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS NOx ppm used for all units)	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS SO2 ppm used for all units)	Be, Cd, Cu, Pb, - Calc_FGV x stack test conc.	All others
<b>Bayswater 2012/13</b>	DM – Stack test FGV rate x test conc.	DM – Stack test FGV rate x test conc.	PM <sub>10</sub> x 0.58	Mass balance	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS NOx ppm used for all units)	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS SO2 ppm used for all units)	N/A	All
<b>Bayswater 2011/12</b>	DM – Stack test FGV rate x test conc.	DM – Stack test FGV rate x test conc.	PM <sub>10</sub> x 0.58	DM – Stack test FGV rate x test conc.	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS NOx ppm used for all units)	DM - Calc_FGV x CEMS monthly weighted av (Unit 1 CEMS SO2 ppm used for all units)	As, Be, Co, Pb, Se - Calc_FGV x stack test conc. <sup>3</sup>	All others
<b>Eraring 2015/16 2014/15 2013/14 2012/13</b>	DM - Calc_FGV x stack test conc.	TSP x 0.99	TSP x 0.53	DM – Stack test FGV rate x test conc.	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	Hg – Calc_FGV x stack test conc.	All others
<b>Eraring 2011/12</b>	DM – Stack test FGV rate x test conc.	TSP x 0.99	TSP x 0.53	DM – Stack test FGV rate x test conc.	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	Hg – Calc_FGV x stack test conc. <sup>4</sup>	All others

<sup>1</sup> DM = direct measurement (periodic or continuous) stack tests, Calc\_FGV = calculated flue gas volume, stack test conc. is the measured stack test pollutant concentration.

<sup>2</sup> CEMS = continuous emission monitoring (direct measurement)

<sup>3</sup> The use of a calculated flue gas volume (Calc\_FGV) was not approved for estimation of particles, metals or Fluoride until December 2012

<sup>4</sup> The use of a calculated flue gas volume (Calc\_FGV) was not approved for estimation of particles, metals or Fluoride until December 2012

<b>Liddell 2015/16 2014/15</b>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	As, Be, Cd, Cu, Pb, Hg - Calc_FGV x stack test conc.	All others
<b>Liddell 2013/14</b>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	As, Be, Hg - Calc_FGV x stack test conc.	All others
<b>Liddell 2012/13</b>	DM – Stack test FGV rate x test conc.	DM – Stack test FGV rate x test conc.	PM <sub>10</sub> x 0.58	DM – Stack test FGV rate x test conc.	DM - Calc_FGV x CEMS monthly weighted av	Mass balance	As – Meas FGV x stack test conc.	All others
<b>Liddell 2011/12</b>	DM – Stack test FGV rate x test conc.	DM – Stack test FGV rate x test conc.	PM <sub>10</sub> x 0.58	DM – Stack test FGV rate x test conc.	DM - Calc_FGV x CEMS monthly weighted av	Mass balance	N/A	All
<b>Mount Piper 2015/16 (2015 CY) 2014/15 (2014 CY) 2013/14 (2013 CY) 2012/13(2012 CY)</b>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc.	PEMS conc. x Calc_FGV	Mass balance	As,Hg,Pb, Dioxins - Calc_FGV x stack test conc.	All others
<b>Mount Piper 2011/12 (2011 CY)</b>	DM - Calc_FGV x stack test conc. <sup>4</sup>	DM - Calc_FGV x stack test conc. <sup>4</sup>	PM <sub>10</sub> x 0.58	DM - Calc_FGV x stack test conc. <sup>4</sup>	PEMS conc. x Calc_FGV	Mass balance	As, Hg ,Pb, Dioxins - Calc_FGV x stack test conc. <sup>4</sup>	All others
<b>Vales Point 2015/16 2014/15 2013/14 2012/13</b>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x stack test conc.	PM <sub>10</sub> x 0.53 <sup>5</sup>	DM - Calc_FGV x stack test conc.	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	As, Pb, Hg - Calc_FGV x stack test conc.	All others
<b>Vales Point 2011/12 (2011 CY)</b>	DM – Test mass rate x op time.	DM – Test mass rate x op time.	PM <sub>10</sub> x 0.58	DM – Test mass rate x op time	DM - Calc_FGV x CEMS monthly weighted av	DM - Calc_FGV x CEMS monthly weighted av	As, Pb, Hg - Test mass rate x op time.	All others

<sup>5</sup> The use of a size factor to calculate PM<sub>2.5</sub> is approved and published in table 5 of the NPI emission estimation manual, however the 0.53 factor should be multiplied by total solid particles not PM<sub>10</sub>. The correct size factor to estimate PM<sub>2.5</sub> from PM<sub>10</sub> is 0.58.

Figure 1 – Reported Annual PM<sub>10</sub> and PM<sub>2.5</sub> Emissions and Emissions Intensity





Figure 2 – Plots of kg of PM<sub>10</sub> per MWh electricity versus annual average stack test concentration for NPI reporting periods 2011/12 to 2015/16 (Blue data points are most recent reporting periods using the calculated flue gas volume, orange data points are earlier years using stack test measured FGV)






Table 2 – PM<sub>2.5</sub> to PM<sub>10</sub> ratios and calculated baghouse total solid particle (TSP) Control Efficiency.

Station	Year	Av TSP (mg/m <sup>3</sup> )	Av PM10 (mg/m <sup>3</sup> )	Av P10:TSP	TSP Control Eff.	TSP Emission %	5 year Av TSP Control	5 year Av TSP Emission %
Bayswater	2015/16	13.7	4.5	33%	99.950%	0.050%		
Bayswater	2014/15	10.9	7.1	65%	99.964%	0.036%		
Bayswater	2013/14	9.0	4.9	55%	99.969%	0.031%		
Bayswater	2012/13	13.8	6.1	44%	99.907%	0.093%		
Bayswater	2011/12	12.2	6.5	53%	99.947%	0.053%	99.948%	0.052%
Eraring	2015/16	6.6	-	-	99.975%	0.025%		
Eraring	2014/15	17.0	-	-	99.927%	0.073%		
Eraring	2013/14	10.0	-	-	99.962%	0.038%		
Eraring	2012/13	10.4	-	-	99.958%	0.042%		
Eraring	2011/12	7.8	-	-	99.966%	0.034%	99.957%	0.043%
Liddell	2015/16	34.5	9.5	27%	99.883%	0.117%		
Liddell	2014/15	19.8	9.5	48%	99.935%	0.065%		
Liddell	2013/14	18.8	9.1	49%	99.942%	0.058%		
Liddell	2012/13	19.0	10.7	56%	99.939%	0.061%		
Liddell	2011/12	21.8	17.0	78%	99.935%	0.065%	99.927%	0.073%
Mt Piper	2015/16	2.9	0.90	31%	99.988%	0.012%		
Mt Piper	2014/15	11.0	7.30	66%	99.953%	0.047%		
Mt Piper	2013/14	13.4	10.18	76%	99.942%	0.058%		
Mt Piper	2012/13	12.5	8.85	71%	99.951%	0.049%		
Mt Piper	2011/12	8.5	6.60	78%	99.967%	0.033%	99.960%	0.040%
Vales Point	2015/16	2.20	0.85	39%	99.988%	0.012%		
Vales Point	2014/15	3.55	1.46	41%	99.981%	0.019%		
Vales Point	2013/14	2.61	2.00	77%	99.987%	0.013%		
Vales Point	2012/13	0.46	0.27	58%	99.998%	0.002%		
Vales Point	2011	9.83	4.64	47%	99.939%	0.061%	99.979%	0.021%