



Environment Protection Licence

Licence - 10555

Licence Details	
Number:	10555
Anniversary Date:	01-July

Licensee	
SYDNEY WATER CORPORATION	
PO BOX 399	
PARRAMATTA NSW 2124	

Premises	
PICTON SEWAGE TREATMENT SYSTEM INCLUDING STP AT	
REMEMBRANCE DRIVE	
PICTON NSW 2571	

Scheduled Activity	
Sewage treatment	

Fee Based Activity	Scale
Sewage treatment processing by small plants	> 1000-5000 ML annual maximum volume of discharge

Contact Us	
NSW EPA	
6 Parramatta Square	
10 Darcy Street	
PARRAMATTA NSW 2150	
Phone: 131 555	
Email: info@epa.nsw.gov.au	
Locked Bag 5022	
PARRAMATTA NSW 2124	



Environment Protection Licence

Licence - 10555

INFORMATION ABOUT THIS LICENCE	5
Dictionary	5
Responsibilities of licensee	5
Variation of licence conditions	5
Duration of licence	5
Licence review	5
Fees and annual return to be sent to the EPA	5
Transfer of licence	6
Public register and access to monitoring data	6
1 ADMINISTRATIVE CONDITIONS	7
A1 What the licence authorises and regulates	7
A2 Premises or plant to which this licence applies	7
A3 Other activities	8
A4 Information supplied to the EPA	8
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND	8
P1 Location of monitoring/discharge points and areas	8
3 LIMIT CONDITIONS	10
L1 Pollution of waters	10
L2 Load limits	10
L3 Concentration limits	12
L4 Volume and mass limits	14
L5 Waste	14
L6 Noise limits	15
L7 Other limit conditions	15
4 OPERATING CONDITIONS	17
O1 Activities must be carried out in a competent manner	17
O2 Maintenance of plant and equipment	17
O3 Emergency response	17
O4 Processes and management	17
O5 Other operating conditions	18
5 MONITORING AND RECORDING CONDITIONS	19
M1 Monitoring records	19
M2 Requirement to monitor concentration of pollutants discharged	20
M3 Testing methods - concentration limits	22
M4 Testing methods - load limits	22



Environment Protection Licence

Licence - 10555

M5	Environmental monitoring	22
M6	Recording of pollution complaints	23
M7	Telephone complaints line	23
M8	Requirement to monitor volume or mass	24
M9	Requirement to record bypass incidents from sewage treatment plants	25
M10	Other monitoring and recording conditions	25
6	REPORTING CONDITIONS	26
R1	Annual return documents	26
R2	Notification of environmental harm	27
R3	Written report	28
R4	Other notifications	28
R5	Annual system performance report	29
R6	Other reporting conditions	34
7	GENERAL CONDITIONS	32
G1	Copy of licence kept at the premises or plant	32
G2	Contact number for incidents and responsible employees	32
G3	Signage	32
G4	Other general conditions	32
8	POLLUTION STUDIES AND REDUCTION PROGRAMS	33
U1	Pollution Study 308: Dry weather overflow abatement program 2025-2029	33
U2	Pollution Study: Waterway health monitoring and adaptive management	34
U3	Pollution Study: Macroalgae trial detailed assessment	35
U4	Pollution Study: Investigation into reducing phosphorus concentrations	36
U5	Pollution Study: Investigation to reduce inflows	37
U6	Pollution Reduction Program: Reduce pollutant concentrations and loads	38
U7	Pollution Study: Investigation into managing effluent	38
U8	Pollution Study: assessment of extreme wet weather discharges	39
U9	Pollution Study 309: Development of choke prioritisation methodologies to produce choke improvement prioritisation lists	40
U10	PRP 308: Choke Improvement Pollution Reduction Program	41
9	SPECIAL CONDITIONS	41
E1	Sydney Water Dry Weather Sewage Overflow Response Report	41
E2	Mandatory Environmental Audit	45
E3	Long Term Solution	54
E4	Special Dictionary	54
	DICTIONARY	55



Environment Protection Licence

Licence - 10555

General Dictionary -----55

Environment Protection Licence

Licence - 10555

Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act);
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).



Environment Protection Licence

Licence - 10555

The EPA publication “A Guide to Licensing” contains information about how to calculate your licence fees. The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

SYDNEY WATER CORPORATION
PO BOX 399
PARRAMATTA NSW 2124

subject to the conditions which follow.



Environment Protection Licence

Licence - 10555

1 Administrative Conditions

A1 What the licence authorises and regulates

- A1.1 This licence authorises the carrying out of the scheduled development work listed below at the premises listed in A2: Not applicable.
- A1.2 This licence authorises the carrying out of the scheduled activities listed below at the premises specified in A2. The activities are listed according to their scheduled activity classification, fee-based activity classification and the scale of the operation.

Unless otherwise further restricted by a condition of this licence, the scale at which the activity is carried out must not exceed the maximum scale specified in this condition.

Scheduled Activity	Fee Based Activity	Scale
Sewage treatment	Sewage treatment processing by small plants	> 1000 - 5000 ML annual maximum volume of discharge

- A1.3 Not applicable.
- A1.4 The objectives of this licence are to:
- a) require practical measures to be taken to protect the environment and public health from sewage treatment plant effluent and sewer overflows;
 - b) require proper and efficient management of the sewage treatment system to minimise harm to the environment and public health;
 - c) require no deterioration and continuing improvement in the sewage treatment system environmental performance relative to existing conditions; and
 - d) minimise the frequency and volume of overflows and sewage treatment plant bypasses.
- A1.5 This licence is to be construed in a manner that will promote the objectives referred to in A1.4.

A2 Premises or plant to which this licence applies

- A2.1 The licence applies to the following premises:

Premises Details
PICTON SEWAGE TREATMENT SYSTEM INCLUDING STP AT
REMEMBRANCE DRIVE
PICTON
NSW 2571



Environment Protection Licence

Licence - 10555

LOT 52 DP 251857, LOT 53 DP 251857, LOT 54 DP 251857, LOT 55 DP 251857, LOT 56 DP 251857, LOT 1 DP 583248, LOT 2 DP 583248, LOT 1 DP 778862, LOT 2 DP 778862, LOT 1 DP 818863, LOT 2 DP 818863, LOT 1 DP 865604, LOT 57 DP 979250, LOT 58 DP 979250, LOT 59 DP 979250, LOT 60 DP 979250, LOT 61 DP 979250, LOT 62 DP 979250, LOT 2 DP 1042285

A2.2 The premises also includes the reticulation system owned and operated by the licensee that is associated with the sewage treatment plant(s) identified in condition A2.1.

A3 Other activities

A3.1 This licence applies to all other activities carried on at the premises, including:

Ancillary Activity
Chemical Storage
Composting
Waste Storage

A4 Information supplied to the EPA

A4.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- a) the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- b) the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

2 Discharges to Air and Water and Applications to Land

P1 Location of monitoring/discharge points and areas

- P1.1 Air monitoring points - not applicable.
- P1.2 The following utilisation areas referred to in the table below are identified in this licence for the purposes of the monitoring and/or the setting of limits for any application of solids or liquids to the utilisation area.
- P1.3 The following points referred to in the table are identified in this licence for the purposes of the monitoring and/or the setting of limits for discharges of pollutants to water from the point.

Environment Protection Licence

Licence - 10555

Water and land

EPA Identification no.	Type of Monitoring Point	Type of Discharge Point	Location Description
1	Volume monitoring Effluent quality monitoring		Effluent quality monitoring at the discharge pipeline from the Western Dam to Stonequarry Creek. Flow monitoring at the discharge from the Western Dam. Marked point 1 on the Picton process flow diagram dated 12 April 2023.
10	Volume Monitoring		Stonequarry Creek Flow measurement point. Sydney Water point 2122006 (downstream of Point 14). Marked point 10 on the Picton process flow diagram dated 12 April 2023.
11	Volume monitoring Effluent quality monitoring Discharge to recycled water utilisation area	Volume monitoring Effluent quality monitoring Discharge to recycled water utilisation area	Recycled Water. Outlet of Eastern Dam. Marked point 11 on the Picton process flow diagram dated 12 April 2023.
12		Discharge to treatment plant utilisation area	Internal Reuse. Outlet of Western Dam marked point 12 on the Picton process flow diagram dated 12 April 2023.
13	Volume monitoring Effluent quality monitoring Discharge to recycled water utilisation area	Volume monitoring Effluent quality monitoring Discharge to recycled water utilisation area	Recycled Water. Outlet of Western Dam marked point 13 on the Picton process flow diagram dated 12 April 2023.
14		Discharge to waters	Discharge point to Stonequarry Creek marked point 14 on the Picton process flow diagram dated 12 April 2023.
15	Volume Monitoring		Flow upstream of the Picton STP discharge point in Stonequarry Creek. Sydney Water Point 2122006U (upstream of Point 14), marked point 15 on the Picton process flow diagram dated 12 April 2023.
16	Level monitoring		Eastern Dam, marked point 16 on the Picton process flow diagram dated 12 April 2023.
17	Level monitoring		Western Dam, marked point 17 on the Picton process flow diagram dated 12 April 2023.
18	Volume monitoring		Flow arriving from the rising main from pumping station SP0914 to Picton STP marked point 18 on the Picton process flow diagram dated 12 April 2023.



Environment Protection Licence

Licence - 10555

19	Volume monitoring	Flow arriving from the rising main from pumping station SP0920 to Picton STP marked point 19 on the Picton process flow diagram dated 12 April 2023.
----	-------------------	--

P1.4 P1.4 For the purposes of conditions L2.1, L2.2, L2.7, L2.8 and L2.9, the sewage treatment plant discharges to Yarramundi 1 sub-zone. Yarramundi sub-zone is the area labelled ‘Yarramundi 1’ on the zone map held on EPA electronic file EF15/791.

3 Limit Conditions

L1 Pollution of waters

- L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.
- L1.2 Subject to the conditions of this licence, sewage must not be discharged from the components of the reticulation system except from those components identified on the system map.
- L1.3 Notwithstanding the provisions of the condition above, this licence does not permit the pollution of waters at any time during dry weather from:
 - a) uncontrolled overflows, or
 - b) directed overflows other than from sewage pumping stations,if a cause of the pollution is failure to:
 - i) operate any part of the reticulation system in a proper and efficient manner; or
 - ii) maintain any part of the reticulation system in a proper and efficient condition.
- L1.4 This licence does not permit the pollution of water at any time during dry weather from any pumping station. This condition is effective from 1 July 2006.

L2 Load limits

- L2.1 The actual load of an assessable pollutant discharged from the premises during the reporting period must not exceed the load limit specified for the assessable pollutant in the table below.

Note: An assessable pollutant is a pollutant which affects the licence fee payable for the licence.
- L2.2 From 1 July 2024, the load limits for Nitrogen (total) and Phosphorus (total) listed in L2.1 will change to the following values:
 - a) Nitrogen (total) 39,700 kg/year
 - b) Phosphorus (total) 720 kg/year
- L2.3 The actual load of an assessable pollutant must be calculated in accordance with the relevant load calculation protocol.



Environment Protection Licence

Licence - 10555

Assessable Pollutant	Load limit (kg)
BOD (Enclosed Water)	2400.00
Nitrogen (total) (Enclosed Water)	4400.00
Oil and Grease (Enclosed Water)	292.00
Phosphorus (total) (Enclosed Water)	80.00
Total suspended solids (Enclosed Water)	2400.00

- L2.4 For the purposes of condition L2.1 only, premises means the sewage treatment plant(s) referred to in condition A2.1 of this licence.
- L2.5 For the purposes of condition L2.2 and M1.1 the relevant load calculation protocol is the methodology detailed in the document titled “Development of Load Calculation Method and Trial Calculation” (June 2003) approved by the EPA in September 2003 and any subsequent amendments approved by the EPA in writing.
- L2.6 Not applicable.
- L2.7 From 1 July 2024, the annual load of Nitrogen (total) and Phosphorus (total) discharged from Sydney Water’s sewage treatment plants in the Yarramundi sub-zone 1 must not result in the aggregated 5 year rolling average load of Nitrogen (total) and Phosphorus (total) exceeding the specified aggregate loads in condition L2.2 in a given year:
a) Nitrogen (total) 39,700 kg/year
b) Phosphorus (total) 720 kg/year
- Note: The loads for the 2024/25 year will be the rolling average of reporting period loads from 2019/20 to 2023/24. Where there have been STP upgrades during this period, the historical loads would be reduced by the load reductions achieved by the upgrades, to obtain an equivalent historical load for use in the rolling average calculations.
- L2.8 From 1 July 2024, the annual load targets from Sydney Water’s sewage treatment plants discharging to Yarramundi sub-zone 1 are the following aggregated 5 year rolling average loads of Nitrogen (total) and Phosphorus (total):
a) Nitrogen (total) 36,100 kg/year
b) Phosphorus (total) 660 kg/year
- Note: The loads for the 2024/25 year will be the rolling average of reporting period loads from 2019/20 to 2023/24. Where there have been STP upgrades during this period, the historical loads would be reduced by the load reductions achieved by the upgrades, to obtain an equivalent historical load for use in the rolling average calculations
- L2.9 The licensee may use nutrient load offset trading to reduce or increase the aggregated 5 year rolling average load of Nitrogen (total) and Phosphorus (total) in L2.7 and L2.8 in accordance with the protocol detailed in the document titled “Compliance offsets for nutrient discharges to the Hawkesbury-Nepean River - Interim Operational Protocol 2018 to 2024 (July 2019)” by BDA Group held on EPA electronic file EF15/791.



Environment Protection Licence

Licence - 10555

L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table/s below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 Where a pH quality limit is specified in the table, the specified percentage of samples must be within the specified ranges.
- L3.3 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table/s.
- L3.4 Water and/or Land Concentration Limits

POINT 11

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	3DGM concentration limit	100 percentile concentration limit
BOD	milligrams per litre	10	15		
Faecal Coliforms	colony forming units per 100 millilitres	2000	10000	-	-
Nitrogen (ammonia)	milligrams per litre	2	5	-	-
Nitrogen (total)	milligrams per litre	10	15	-	-
pH	pH	6.5-9.5	-	-	-
Phosphorus (total)	milligrams per litre	8	9		
Total suspended solids	milligrams per litre	120	480		

POINT 13

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	3DGM concentration limit	100 percentile concentration limit
BOD	milligrams per litre	7	10	-	-
Faecal Coliforms	colony forming units per 100 millilitres	-	200*	-	-



Environment Protection Licence

Licence - 10555

Nitrogen (ammonia)	milligrams per litre	0.5	1	-	-
Nitrogen (total)	milligrams per litre	6	10	-	-
pH	pH	6.5-9.5	-	-	-
Phosphorus (total)	milligrams per litre	0.2	0.4	-	-
Total suspended solids	milligrams per litre	7	15	-	-

POINT 14

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	3DGM concentration limit	100 percentile concentration limit
BOD	milligrams per litre	2	5	-	-
Faecal Coliforms	colony forming units per 100 millilitres	-	200*	-	-
Nitrogen (ammonia)	milligrams per litre	0.5	1	-	-
Nitrogen (total)	milligrams per litre	4.5	7	-	-
Phosphorus (total)	milligrams per litre	0.15	0.3	-	-
Total suspended solids	milligrams per litre	5	10	-	-

Note: The faecal coliforms concentration limit marked by an asterix in the above table is to be interpreted as an 80% concentration limit for the purpose of assessing compliance with this condition.

L3.5 From 1 July 2024, the concentration limit for Phosphorus (total) listed in L3.4 for Point 14 will change to 0.1 mg/L (50 percentile concentration limit).

Note: The 100 percentile limits for Nitrogen (total) and Phosphorus(total) will cease to apply from 1 July 2024.

L3.6 Not applicable.

L3.7 Not applicable.



Environment Protection Licence

Licence - 10555

L3.8 Toxicity limits

Not applicable.

L3.9 In the case of a pollutant which is subject to a 3DGM limit, only the samples collected on the first day of the 3DGM sampling are to be used for the calculation of the percentile.

L3.10 Notwithstanding condition L3.2 above, when the pH of the effluent discharged at Point 11 and Point 13 is elevated due to algal problems in the irrigation dam:

- a) application of effluent to the irrigation utilisation area may continue to be undertaken; and
- b) exceedance of the upper value of the 50 percentile concentration limit for pH is permitted where algae in the dam was the sole cause of the exceedance.

L4 Volume and mass limits

L4.1 For each discharge point or utilisation area specified below (by a point number), the volume/mass of:

- a) liquids discharged to water; or;
- b) solids or liquids applied to the area;

must not exceed the volume/mass limit specified for that discharge point or area.

Point	Unit of Measure	Volume/Mass Limit
14	kilolitres per day	15000

L4.2 In addition to the volume/mass limit imposed at Point 14 by condition L4.1, the following volume/mass limits apply at Point 14 for precautionary discharges to Stonequarry Creek until 31 December 2032:

- a) 0 kilolitres per day, when creek flow at Point 10 is less than or equal to 2,500 kilolitres per day.
- b) up to 50% of combined downstream flow at Point 10, when creek flow at Point 15 is greater than 2,500 kilolitres per day, and less than or equal to 5,000 kilolitres per day.
- c) Up to 67% of combined downstream flow at Point 10, when the creek flow at Point 15 is greater than 5,000 kilolitres per day.

L4.3 In addition to the volume/mass limit imposed at Point 14. The following volume limits apply for discharges to maintain storage capacity at Point 14 until 31 December 2032:

- a) Up to 100% of the total daily inflow volume measured at Point 18 and Point 19 may be discharged at any time when the combined volume in the dams reaches 80% of the total storage as measured at Point 16 and 17. Discharges must cease when the combined volume in the dams as measured at Point 16 and 17 reaches 75% of the total storage.
- b) To prepare for anticipated extreme wet weather, when forecast rainfall is anticipated to exceed a total of 90mm rainfall over the next five days, treated effluent may be discharged at anytime when the combined volume in the dams exceeds 50% of the total storage capacity measured at Point 16 and Point 17.

L5 Waste

Environment Protection Licence

Licence - 10555

- L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.
- L5.2 This condition only applies to the storage, treatment, processing, reprocessing or disposal of waste at the premises if those activities require an environment protection licence.
- L5.3 The licensee may receive and/or transfer sewage generated outside the premises for treatment, processing or reprocessing at the premises. The licensee must take reasonable steps to ensure that sewage received at the premises has been lawfully discharged in accordance with a trade waste agreement or customer contract (as applicable) in force between the licensee and the generator of the waste. The licensee must treat, process or reprocess the sewage in accordance with this licence prior to discharge from the premises.
- L5.4 The licensee may receive, store, treat, process or reprocess and/or transfer at the premises sewage products generated or stored outside the premises by the licensee's other sewage treatment systems. Sewage products must be received, treated, processed or reprocessed in accordance with this licence.

L6 Noise limits

- L6.1 Not applicable.

L7 Other limit conditions

L7.1 Hydraulic Sewer System Model

- a) The licensee must maintain a hydraulic sewer system model which has no temporal or magnitude bias in either flow volume or water levels at the licence gauges as referenced in the document titled "PRP101.1 System Model Performance Indicators, September 2000" and subsequent modifications made by the Criteria Review Committee.
- b) The licensee must undertake an annual Quality System audit of the hydraulic sewer system model to determine if the model used during that reporting period meets the standards set out in condition L7.1(a).
- c) The licensee must prepare a written report on each Quality System audit of any model used to assess sewage system wet weather overflow performance for the purpose of determining compliance with this licence. The report must also include the Pearson's correlation coefficient for the model used during the reporting period.
- d) The licensee must provide a written report with each Annual Return on any Quality System audit of the hydraulic sewer system model stating the methodology and results of the audit.
- e) The licensee must convene an Independent Criteria Review Committee at least once every three Reporting Periods to review the methodology and findings of each of the Quality System audits.
- f) The licensee must ensure that the Independent Criteria Review Committee prepares a written report on the review required by condition L7.1(e).
- g) The licensee must submit to the EPA a copy of each Independent Criteria Review Committee report received by the licensee in a particular Reporting Period with the following Annual Sewage Treatment System Performance Report required by condition R5 of this licence.

Environment Protection Licence

Licence - 10555

L7.2 Wet weather overflow limits

Not applicable.

L7.3 Not applicable.

L7.4 Dry weather overflow limits

Not applicable.

L7.5 Choke improvement requirements

Note: The objective of this condition is to require continuous reductions in impacts to the environment and community from chokes by requiring the licensee to achieve set improvement levels within defined periods based on abatement works in prioritised areas.

a) By 31 December 2024 and then again by 31 December 2027, and thereafter at intervals of not greater than every five years, the licensee must submit to the EPA a proposed choke improvement prioritisation list. The list must be based on the scope of all the areas in Sydney Water's licensed reticulation systems.

b) For the purposes of producing the choke improvement prioritisation list as required by condition L7.5a), the licensee must determine the prioritisation of choke improvement areas using the applicable methodologies developed in accordance with the relevant conditions of Pollution Study 309.

Note: Upon acceptance by the EPA, the choke improvement prioritisation list will form the basis for an associated improvement level imposed under PRP 308, and the licensee will have a maximum of five years to achieve that improvement level.

c) The licensee must achieve the improvement levels in PRP 308 by the associated completion date specified.

d) Within three months after a completion date specified in PRP 308, the licensee must provide a report to the EPA demonstrating compliance or otherwise with condition L7.5c).

L7.6 Utilisation Areas

Liquids must only be applied to liquids utilisation areas for which a discharge point or area has been identified in P1 of this licence.

L7.7 Spray from liquids application must not drift beyond the boundary of the utilisation area to which it is applied.

L7.8 Biosolids must only be applied to utilisation areas as defined in the map titled "Map 1 Picton Farm" dated 6 April 2016.

4 Operating Conditions



Environment Protection Licence

Licence - 10555

O1 Activities must be carried out in a competent manner

- O1.1 Licensed activities must be carried out in a competent manner.
This includes:
- a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
 - b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.
- O1.2 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed in accordance with the Biosolids Guidelines, or as otherwise approved in writing by the EPA.

O2 Maintenance of plant and equipment

- O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
- a) must be maintained in a proper and efficient condition; and
 - b) must be operated in a proper and efficient manner.

O3 Emergency response

- O3.1 In the event of an overflow from the reticulation system or a bypass from a sewage treatment plant that harms or is likely to harm the environment or present a significant public health risk, the licensee must take all reasonable and feasible actions as soon as practicable to minimise the impact of the overflow or bypass on the environment and public health.

For the avoidance of doubt, the requirements of this condition are in addition to any measures required to be implemented in accordance with the Pollution Incident Response Management Plan required to be prepared and implemented under Part 5.7A of the Protection of the Environment Operations Act 1997.

O4 Processes and management

O4.1 Appropriate Treatment Processes

Sewage or effluent must not be discharged from points 11, 13 and 14 unless it has been treated in accordance with the requirements of the table below.

Required treatment process	Flow range
Screening, biological treatment, filtration and disinfection (full tertiary treatment)	All flows to the Western Dam which discharge to utilisation area (Point 13) or to Stonequarry Creek (Point 14)
Screening, biological treatment (secondary treatment)	All flows to the Eastern dam which discharge to utilisation area (Point 11)

- O4.2 Not applicable.

Environment Protection Licence

Licence - 10555

O4.3 Not applicable.

O4.4 Not applicable.

O4.5 Not applicable.

O4.6 Not applicable.

O4.7 Level of reticulation system management, operations and maintenance activities

Not applicable.

O4.8 Not applicable.

O4.9 Exceedance of design capacity of primary disinfection processes

Not applicable.

O5 Other operating conditions

O5.1 Prohibition on acceptance of pesticides

The licensee must not consent to any discharge of organophosphate pesticides (including chlorpyrifos, diazinon, malathion) or organochlorine pesticides (including dieldrin, heptachlor and chlordane) into the sewage treatment system.

O5.2 Not applicable.

O5.3 Not applicable.

O5.4 Not applicable.

O5.5 Not Applicable.

O5.6 Effluent disposal must be preferentially carried out by sustainable effluent irrigation.

O5.7 Management of Utilisation Area

The quantity of effluent/solids applied to the utilisation area must not exceed the capacity of the area to effectively utilise the effluent/solids.

Note: For the purpose of this condition, 'effectively utilise' includes the use of the effluent/solids for pasture or crop production, as well as the ability of the soil to absorb the nutrient, salt, hydraulic load and organic material.

O5.8 Effluent application

a) Effluent application must not occur in a manner that causes surface runoff.

Environment Protection Licence

Licence - 10555

- b) Spray from effluent application must not drift beyond the boundary of the premises.
- c) Livestock access to any effluent application area must be denied during effluent application and until the applied effluent area has dried.
- d) All effluent application operations and activities occurring at the premises must be carried out in a manner that will minimise dust at the boundary of the utilisation area.
- e) The licensee must not cease to use the utilisation area (Points 11 and 13 in this licence) without the prior written approval of the EPA to an alternative means of disposal of the effluent. Any such written approval is intended to be effected for the purposes of this condition by variation of this licence.
- f) Effluent liquid waste pipelines and fittings must be clearly identified. Standard watertaps, hoses and valves must not be fitted to the pipelines of the effluent system. The effluent system must not be connected to other pipelines. Lockable valves or removable handles must be used where there is public access to the effluent.
- g) Public access to any effluent utilisation area must be denied during effluent application and until the effluent application area has dried.
- h) Adequate notices, warning the public not to drink or otherwise use the treated effluent, must be erected on the site. These notices must be legible English and in any other languages as may be necessary, and must indicate at least that the water in use is "Reclaimed Water - Unfit for Drinking".
- i) Pasture or fodder crops must not be harvested before the effluent utilisation area has dried.

5 Monitoring and Recording Conditions

M1 Monitoring records

- M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.
- M1.2 All records required to be kept by this licence must be:
 - a) in a legible form, or in a form that can readily be reduced to a legible form;
 - b) kept for at least 4 years after the monitoring or event to which they relate took place; and
 - c) produced in a legible form to any authorised officer of the EPA who asks to see them.
- M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:
 - a) the date(s) on which the sample was taken;
 - b) the time(s) at which the sample was collected;
 - c) the point at which the sample was taken; and
 - d) the name of the person who collected the sample.

M1.4 Registers

The licensee must maintain and make available for inspection by the public, at the licensee's Head Office, registers recording the following information, for the sewage treatment system:

- a) a map or maps of the sewage treatment system showing:
 - i) the location of the sewage treatment plant or plants, sewage pumping stations, directed overflow structures, pipes and access chambers in the sewage treatment system, referenced by the licensee's identifier and the EPA point identification number,



Environment Protection Licence

Licence - 10555

- as applicable;
- ii) the catchments, sub-catchments and sensitive areas relevant to the sewage treatment system;
- b) the number of chokes within the system reported to the licensee during each reporting period;
- c) a schedule of proposed works to be carried out in relation to the premises during each reporting period;
- d) the works completed in relation to the premises during each reporting period; and
- e) the complaints by type recorded under M7 during each reporting period.

M1.5 Changes to the system map must be recorded by reference to the date of the change, description of the change and the name of the person authorising the change.

M2 Requirement to monitor concentration of pollutants discharged

M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified in Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

M2.2 Not applicable.

M2.3 Water and/ or Land Monitoring Requirements

POINT 1

Pollutant	Units of measure	Frequency	Sampling Method
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	Grab sample
Faecal Coliforms	colony forming units per 100 millilitres	Special Frequency 1	Grab sample
Nitrogen (ammonia)	milligrams per litre	Special Frequency 1	Grab sample
Nitrogen (total)	milligrams per litre	Special Frequency 1	Grab sample
Phosphorus (total)	milligrams per litre	Special Frequency 1	Grab sample
Total suspended solids	milligrams per litre	Special Frequency 1	Grab sample

POINT 11

Pollutant	Units of measure	Frequency	Sampling Method
Biochemical oxygen demand	milligrams per litre	Special Frequency 2	Grab sample
Faecal Coliforms	colony forming units per 100 millilitres	Special Frequency 2	Grab sample
Nitrogen (ammonia)	milligrams per litre	Special Frequency 2	Grab sample
Nitrogen (total)	milligrams per litre	Special Frequency 2	Grab sample
Phosphorus (total)	milligrams per litre	Special Frequency 2	Grab sample
Total suspended solids	milligrams per litre	Special Frequency 2	Grab sample



Environment Protection Licence

Licence - 10555

POINT 13

Pollutant	Units of measure	Frequency	Sampling Method
BOD	milligrams per litre	Special Frequency 2	Grab sample
Faecal Coliforms	colony forming units per 100 millilitres	Special Frequency 2	Grab sample
Nitrogen (ammonia)	milligrams per litre	Special Frequency 2	Grab sample
Nitrogen (total)	milligrams per litre	Special Frequency 2	Grab sample
Phosphorus (total)	milligrams per litre	Special Frequency 2	Grab sample
Total suspended solids	milligrams per litre	Special Frequency 2	Grab sample

M2.4 For the purposes of the tables above:

- a) Special Frequency 1 means daily during the occurrence of any discharge longer than 2 hours during normal working hours.
- b) Special Frequency 2 means every 6 days when the irrigation system is operating at the time of sampling.

M2.5 Not applicable.

M2.6 The monitoring results collected in accordance with condition M2 for:

- a) Point 1 can be used to determine compliance with the limits in condition L3.4 for Point 14;
- b) Point 11 can be used to determine compliance with the limits in condition L3.4 for Point 11; and
- c) Point 13 can be used to determine compliance with the limits in condition L3.4 for Point 13.

M2.7 Subject to M2.8, where the licensee is unable to carry out any sampling required under condition M2 at the required frequency or interval or both because of a circumstance set out in column 1 of the Table below, the licensee is taken to have carried out the sampling at the required frequency or interval or both, as the case may be, if the licensee collects the required sample within the corresponding timeframe in column 2 of the Table.

No.	Column 1	Column 2
1	The unforeseen loss of power supply to the essential monitoring equipment that cannot be rectified by the reasonable provision and operation of standby generators	Within 48 hours of power being restored to the premises
2	The inability of the licensee to access or safely access the monitoring site or equipment due to tidal or fluvial flooding	As soon as practicable once flooding has ceased or abated
3	The failure or malfunction of essential monitoring equipment caused by tidal or fluvial flooding	Within 48 hours after failure or malfunction of essential monitoring equipment has ceased

M2.8 The licensee must collect and analyse the required number of samples for the reporting period as specified in

Environment Protection Licence

Licence - 10555

conditions M2.3 – M2.5 above.

M2.9 The licensee must keep records of all circumstances listed in column 1 of the Table in condition M2.7 which triggered sample collection in accordance with column 2 of the same Table, including information that can demonstrate that the circumstances in column 1 applied and that the sampling was carried out in accordance with the timeframe prescribed in column 2 of that Table. The licensee must keep these records for a period of 5 years after the end of the reporting period in which the circumstances occurred.

M2.10 The record must be produced to any authorised officer of the EPA who requests to see them.

M3 Testing methods - concentration limits

M3.1 Not applicable.

M3.2 Subject to any express provision to the contrary in this licence, monitoring for the concentration of a pollutant discharged to waters or applied to a utilisation area must be done in accordance with the Approved Methods Publication unless another method has been approved by the EPA in writing before any tests are conducted.

M3.3 The requirements of condition M3.2 also apply to the monitoring of the concentration of pollutants in waters.

M4 Testing methods - load limits

Note: Division 4 of the *Protection of the Environment Operations (General) Regulation 2022* requires that monitoring of actual loads of assessable pollutants listed in L2.2 must be carried out in accordance with the relevant load calculation protocol set out for the fee-based activity classification listed in the Administrative Conditions of this licence.

M5 Environmental monitoring

M5.1 Sydney Water Aquatic Monitoring (SWAM) Program

a) From 1 July 2023 onward, the licensee must undertake the monitoring programs detailed in the Sydney Water publication "Sydney Water Aquatic Monitoring (SWAM) Program, Version 1, April 2023", or in any replacement document approved in writing by the EPA.

b) The licensee must maintain a database of the results obtained in undertaking monitoring programs specified in the document cited above, as well as monitoring programs previously undertaken under the publication "Sewage Treatment System Impact Monitoring Program, December 2010" (the STSIMP Document). Information from the database must be made available to any authorised officer of the EPA on request.

c) The licensee must provide to the EPA the reports specified in the document cited above.

d) The "SWAM Annual Data Report: All regions" specified in the document cited above must be submitted not later than 15 December in each year.

Environment Protection Licence

Licence - 10555

e) The "SWAM Interpretative Report – Inland, estuarine, lagoon and nearshore marine waters" and "SWAM Interpretative Report – Offshore marine waters" (the SWAM Interpretative Reports) specified in the document cited above must be submitted in the first year of each new pricing cycle for the licensee as determined by the NSW Independent Pricing and Regulatory Tribunal (IPART).

f) For the purposes of condition e) above, the next SWAM Interpretative Reports must be submitted by 31 December 2025.

g) The licensee must continue to undertake the monitoring programs and reporting specified in the STSIMP Document until the commencement of the SWAM Program. This includes:

- i) the continuation of monitoring programs in the STSIMP Document until 30 June 2023
- ii) the provision of the "Sewage Treatment System Impact Monitoring Program (STSIMP): Annual Data Report" to the EPA by no later than 15 December 2023.

Note: Copies of reports relating to the SWAM Program can be found at:

<https://www.sydneywater.com.au/water-the-environment/how-we-manage-sydneys-water/wastewater-network/wastewater-monitoring.html>

M6 Recording of pollution complaints

M6.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.

M6.2 The record must include details of the following:

- a) the date and time of the complaint;
- b) the method by which the complaint was made;
- c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
- d) the nature of the complaint;
- e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
- f) if no action was taken by the licensee, the reasons why no action was taken.

M6.3 The record of a complaint must be kept for at least 4 years after the complaint was made.

M6.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M7 Telephone complaints line

M7.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.

M7.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.



Environment Protection Licence

Licence - 10555

- M7.3 The preceding two conditions do not apply until 3 months after: the date of the issue of this licence.
- M7.4 For the purpose of this condition, operating hours are defined as twenty four hours a day, seven days a week.

M8 Requirement to monitor volume or mass

- M8.1 For each discharge point or utilisation area specified below, the licensee must monitor:
- a) the volume of liquids discharged to water or applied to the area;
 - b) the mass of solids applied to the area;
 - c) the mass of pollutants emitted to the air;
- at the frequency and using the method and units of measure, specified below.

POINT 1

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Electronic level sensor and continuous logger

POINT 10

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Electronic level sensor and continuous logger

POINT 11

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Electronic level sensor and continuous logger

POINT 13

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Electronic level sensor and continuous logger

POINT 15

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Estimate

POINT 16,17

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres	Electronic level sensor and continuous logger

POINT 18,19

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Flow meter and continuous logger

- M8.2 The monitoring results collected in accordance with condition M8.1 for:
- a) Point 1 can be used to determine compliance with the limits in condition L4.1 for Point 14.

Environment Protection Licence

Licence - 10555

- b) Points 1, 10 and 15 can be used to determine compliance with the limits in condition L4.2 for Points 14.
- c) Point 1 can be used to determine compliance with the limits in condition L4.3 for Point 14.

M8.3 In the event that the licensee cannot comply with a volume monitoring method as required by this licence solely due to the failure or malfunction of essential monitoring equipment, volume may be calculated using another agreed method approved in writing by the EPA. This provision only applies for the duration of the failure or malfunction and the licensee is to rectify the failure or malfunction as soon as practical.

M9 Requirement to record bypass incidents from sewage treatment plants

M9.1 The licensee must record the following details in relation to each bypass from the premises:

- a) the EPA point identification number through which the bypass discharged;
- b) the start time, date and duration of the bypass;
- c) the estimated volume of the bypass;
- d) the level of treatment at the sewage treatment plant prior to discharge;
- e) classification as a dry or wet weather bypass;
- f) the most likely cause of the bypass; and
- g) the name or names of the treatment process or processes bypassed.

M9.2 A dry weather bypass is a bypass that occurs when the inflow rates of sewage to the sewage treatment plant does not exceed 35 L/s and a wet weather bypass occurs when this flow is equalled or exceeded.

M10 Other monitoring and recording conditions

M10.1 Continuation of Monitoring Programs

Not applicable.

M10.2 Biosolids

Biosolids at the premises must be recorded, monitored and classified in accordance with the Biosolids Guidelines, or as otherwise approved in writing by the EPA.

M10.3 Dry weather leakage monitoring program

- a) The licensee must monitor (using results obtained by sampling and analysis) the concentration of faecal coliforms in samples collected from each sampling point identified on the spreadsheet titled "Dry Weather Leakage Monitoring Program SCAMP sampling locations master spreadsheet" and associated maps submitted to the EPA (EPA Reference: SF19/48619).
- b) The licensee must undertake the dry weather leakage monitoring at an annual frequency at each SCAMP monitoring point referenced in M10.3 a), unless subject to clause M10.6, using sampling method grab sample, units of measure of cfu/100mL.
- c) The licensee must seek approval in writing from the EPA to make changes to the dry weather leakage monitoring program SCAMP sampling locations.
- d) Within two weeks of receiving approval from the EPA, the licensee must update the master spreadsheet and associated maps referenced in condition M10.3a and provide the EPA with a copy of the updated documents.

Environment Protection Licence

Licence - 10555

M10.4 Investigations and remedial action for dry weather leakage

- a) The licensee must investigate the cause of faecal coliform presence in samples collected as per M10.3 a) and M10.3 b) where the analysis results indicate an exceedance in the threshold of 10,000 cfu/100mL ("the threshold"). Investigations will be assigned a priority based on potential risk to the environment and public health and commence accordingly.
- b) The licensee must take remedial action where any investigation undertaken identifies the reticulation system as the cause of the exceedance of the threshold for faecal coliform specified in condition M10.4(a).
- c) The licensee must record:
 - i) the method, results and conclusions of investigations undertaken in accordance with condition M10.4(a), and
 - ii) actions taken by the licensee as a result of the conclusions of the investigations.

M10.5 When analysis results of three consecutive annual routine monitoring samples collected at a SCAMP monitoring point referenced in M10.3 a) exceeds the threshold for faecal coliforms specified in condition M10.4 a), the licensee must, in addition to the actions set out in condition M10.4, notify the EPA in writing as soon as practicable, providing the three sample analysis results, identifying the relevant SCAMP and providing the outcomes of any relevant investigations and remediation actions undertaken.

M10.6 When analysis results of three consecutive annual routine monitoring samples collected at a SCAMP monitoring point referenced in M10.3 a) exceeds the threshold for faecal coliforms specified in condition M10.4 a), the licensee must commence sampling at the relevant sampling location referenced in M10.3 a) on a quarterly basis, unless otherwise approved in writing by the EPA. Sampling must be undertaken at quarterly intervals until three consecutive routine samples are below the threshold, at which time the frequency of sampling at the location can revert to an annual frequency as specified in M10.3 b).

6 Reporting Conditions

R1 Annual return documents

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:

1. a Statement of Compliance,
2. a Monitoring and Complaints Summary,
3. a Statement of Compliance - Licence Conditions,
4. a Statement of Compliance - Load based Fee,
5. a Statement of Compliance - Requirement to Prepare Pollution Incident Response Management Plan,
6. a Statement of Compliance - Requirement to Publish Pollution Monitoring Data; and
7. a Statement of Compliance - Environmental Management Systems and Practices.

At the end of each reporting period, the EPA will provide to the licensee notification that the Annual Return is due.



Environment Protection Licence

Licence - 10555

R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

R1.3 Where this licence is transferred from the licensee to a new licensee:

- a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
- b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:

- a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
- b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

R1.5 The Annual Return for the reporting period must be supplied to the EPA via eConnect *EPA* or by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

R1.6 Where the licensee is unable to complete a part of the Annual Return by the due date because the licensee was unable to calculate the actual load of a pollutant due to circumstances beyond the licensee's control, the licensee must notify the EPA in writing as soon as practicable, and in any event not later than the due date. The notification must specify:

- a) the assessable pollutants for which the actual load could not be calculated; and
- b) the relevant circumstances that were beyond the control of the licensee.

R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.

R1.8 Within the Annual Return, the Statements of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:

- a) the licence holder; or
- b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

R2 Notification of environmental harm

Note: The licensee or its employees must notify all relevant authorities of incidents causing or threatening material harm to the environment immediately after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which they

Environment Protection Licence

Licence - 10555

became aware of the incident.

R3 Written report

- R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
- a) where this licence applies to premises, an event has occurred at the premises; or
 - b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence,
- and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.
- R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.
- R3.3 The request may require a report which includes any or all of the following information:
- a) the cause, time and duration of the event;
 - b) the type, volume and concentration of every pollutant discharged as a result of the event;
 - c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
 - d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
 - e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
 - f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
 - g) any other relevant matters.
- R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.
- R3.5 For the purposes of this condition, the definition of event in the Special Dictionary does not apply.

R4 Other notifications

- R4.1 a) Notwithstanding notification requirements under condition R2, the licensee must notify the EPA of incidents where sewage or effluent has been discharged to, or is reasonably expected to be discharged to waterways in the following circumstances:
- i. a dry weather sewage overflow from a sewage pumping station;
 - ii. sewage or effluent not treated at the sewage treatment plant in accordance with the requirements of conditions O4.1 – O4.6; or
 - iii. any treated sewage or effluent discharge released to the environment that is not in accordance with the precautionary discharge requirements at condition L4.3.
- b) Notifications must be made to the EPA by contacting the Environment Line as soon as practicable after the licensee becomes aware of the incident.
- c) The notification should include the relevant information as per s150 of the Protection of Environment Operations Act.
- d) Where an incident has been reported under condition R2 there is no requirement to report it under condition R4 in

Environment Protection Licence

Licence - 10555

addition to the report made under condition R2.

Note: Notifications must be made to the other agencies such as Beachwatch, National Parks and NSW Food Authority, where relevant. The requirements for such notifications must be included in Pollution Incident Response Management Plans.

Note: The reporting requirements in condition R4 do not replace any other reporting requirements in the licence or under the Protection of the Environment Operations Act 1997.

R5 Annual system performance report

R5.1 The licensee must supply to the EPA an Annual Sewage Treatment System Performance report not later than 30 September following the end of each reporting period.

R5.2 The Annual Sewage Treatment System Performance Report is to supplement the Annual Return and must report but not be limited to the following components:

R5.3 Effluent discharged

- a) The percentile values calculated from the monitoring data for each pollutant which has corresponding limits.
- b) The annual load of all assessable pollutants.
- c) An analysis of the sewage treatment plant performance against the concentration, toxicity and load limits specified in the licence.
- d) An assessment of the current year's sewage treatment plant performance against the previous five year's performance. The assessment must include but not be limited to an explanation of any observed trends in the sewage treatment plant performance, and the reason for such trends.
- e) The load of Phosphorous (total) and Nitrogen (total) discharged from the sewage treatment plant expressed as a percentage of the total load of Phosphorous (total) and Nitrogen (total) directly discharged from all Sydney Water sewage treatment systems to the Hawkesbury-Nepean.
- f) The total volume discharged from the sewage treatment plant, and the average volume discharged from the sewage treatment plant during dry weather.
- g) The total volume and percentage volume of effluent recycled.
- h) i) The total number of sewage treatment plant bypasses and the total volume discharged that did not receive required treatment during:
 - AA) dry weather; and
 - BB) wet weather
 ii) A summary report of all bypass events which includes, but is not limited to, the following: classification as a dry or wet weather bypass, duration, volume discharged, volume treated, receiving waters, cause, treatment process(es) bypassed and any action(s) taken.
- i) For each discharge to Stonequarry Creek to maintain storage capacity in the treated effluent storage dams:
 - i) the capacity in the Eastern and Western Dams at the start and finish of discharge, date and time of start and finish of discharge, and the total volume discharged during that time.
 - ii) for each day of anticipated extreme wet weather event discharges, the five-day rainfall volume weather forecast reported by the Bureau of Meteorology at the Camden weather station (ID 9755).
- j) irrigation figures for each monthly period:
 - i) the maximum designed application rate versus actual application rate
 - ii) total irrigatable area versus area irrigated
- k) The amount of daily rainfall measured at a rain gauge at the STP, or at the rain gauge closest to the centre

Environment Protection Licence

Licence - 10555

of the catchment of the sewage treatment system, for each day of the reporting period.

R5.4 Biosolids

Reporting requirements in accordance with the Biosolids Guidelines

R5.5 Reticulation System

- a) Dry weather leakages:
 - i) monitoring results from each SCAMP;
 - ii) outcomes of any investigations; and
 - iii) details of rectification action taken.
- b) Dry weather overflows from chokes and sewage pumping stations:
 - i) including;
 - AA) number of dry weather overflows to waterways, for the whole system and for each SCAMP;
 - BB) total number of dry weather overflows, for the whole system and for each SCAMP;
 - CC) total number of dry weather overflows per 100km for whole system;
 - DD) the name of each sewage treatment system which exceeded the dry weather overflow limit at condition L7.4; and
 - EE) the name of each SCAMP where the number of dry weather overflows reaching waterways in a SCAMP exceeds the target for that SCAMP specified in the SCAMP table below.
 - ii) comparison of the dry weather overflow performance against the previous four twelve month periods for dry weather overflows to waterways and total dry weather overflows.
- c) Where the dry weather overflow sewage treatment system limit at condition L7.4 and/or target in the SCAMP table below was exceeded during the reporting period, the licensee must provide a report to the EPA no later than 30 September each year explaining the reason for the exceedance, which should include but not be limited to:
 - i) an analysis of the exceedances of limit(s) and / or target(s), including the determination of any long-term trends and evaluation of dry weather overflow abatement programs implemented by the licensee;
 - ii) the details of any dry weather overflow abatement investigations, works and activities that were scheduled to be undertaken during the reporting period and which were completed;
 - iii) the details of any dry weather overflow abatement investigations, works and activities that were scheduled to be undertaken during the reporting period and which were not undertaken or not completed;
 - iv) the details of any dry weather overflow abatement investigations, works and activities the licensee will undertake in subsequent reporting periods to minimise the likelihood of the limit(s) and / or target(s) being exceeded in any future reporting period, including the timeframes for those actions to be implemented and the level of prioritisation given to each sewage treatment system and / or SCAMP; and
 - v) an assessment of whether any amendment to the dry weather overflow abatement investigations, works and activities scheduled for the remaining reporting periods to 30 June 2015 is required to achieve the dry weather overflow limits and / or targets at condition L7.4 and in the SCAMP table below.

SCAMP table



Environment Protection Licence

Licence - 10555

SCAMP Name	Dry Weather Overflows Reaching Waterways per Annum
S_PICTON	1

R5.6 Wet weather overflow abatement

Not applicable.

R5.7 Complaints and reports

A breakdown of the total number of complaints and reports received by the licensee in relation to the premises into categories of “odours”, “water pollution – sewage treatment plant”, “water pollution – reticulation system”, and any other category indicated by the complaint/report. A brief description of any significant unresolved issues arising out of the complaints and reports must be provided.

R5.8 The Annual Sewage Treatment System Performance Report must be presented in a format approved in writing by the EPA.

R5.9 Target nutrient loads (applicable from 1 July 2024)

- a) The licensee must report the Nitrogen (total) and Phosphorus (total) from Sydney Water’s sewage treatment plants discharging to Yarramundi sub-zone 1 relative to the annual load targets in condition L2.8 including whether the targets were achieved. The report is to include a summary of any investigations, programs, projects, works or activities, including offsets, that were completed that contributed to the achieving of the targets.
- b) Where the annual load targets were not achieved, the licensee must provide a statement explaining the reasons for exceeding the targets which includes:
 - i. a summary of any investigations, programs, projects, works or activities, including offsets, that were completed with the intent of achieving the targets
 - ii. a summary of any planned investigations, programs, projects, works or activities, including offsets that were not undertaken or completed
 - iii. a summary of what will be done in the next reporting period to achieve the targets including an assessment of whether an amendment to the investigations, programs, projects, works or activities, including offsets is required to achieve the targets in conditions L2.8.

R6 Other reporting conditions

R6.1 Site Specific Risk Management Plan

- The licensee must prepare a site-specific risk management plan to manage the potential risk to human health posed by the discharge of treated effluent to Stonequarry Creek. The plan must:
- a) address the full range of discharge scenarios.
 - b) be updated annually (at minimum).
 - c) include specific management actions and triggers.
 - d) be provided to the EPA upon each update.

Environment Protection Licence

Licence - 10555

R6.2 Site Specific Effluent Management Plan

The licensee must prepare a site-specific effluent management plan to manage the disposal of effluent generated by the Picton sewage treatment plan. The plan must:

- a) address the full range weather conditions.
- b) be updated annually (at minimum).
- c) include specific management actions and triggers.
- d) be provided to the EPA upon each update.

7 General Conditions

G1 Copy of licence kept at the premises or plant

G1.1 A copy of this licence must be kept at the premises to which the licence applies.

G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.

G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

G2 Contact number for incidents and responsible employees

G2.1 The licensee must operate 24-hour telephone contact lines for the purpose of enabling the EPA to directly contact one or more representatives of the licensee who can:

- a) respond at all times to incidents relating to the premises; and
- b) contact the licensee's senior employees or agents authorised at all times to:
 - i) speak on behalf of the licensee; and
 - ii) provide any information or document required under this licence.

G2.2 The licensee is to inform the EPA in writing of the appointment of any contact persons, or changes to the person's contact details as soon as practicable and in any event within fourteen days of the appointment or change.

G3 Signage

G3.1 The location of EPA point number(s) listed in tables P1.1, P1.2 & P1.3 must be clearly marked by signs that indicate the point identification number used in this licence and be located as close as practical to the point.

G4 Other general conditions

G4.1 Completed Programs

Environment Protection Licence

Licence - 10555

Program	Description	Completed Date
Pollution Study: Short-term water quality sampling program	The licensee is required to undertake a short-term water quality sampling program including characterisation of the Picton STP effluent and in-stream water quality sampling of Stonequarry Creek to obtain data to inform further discussions with the EPA.	28-November-2017
Pollution Study: Source control investigations to reduce stormwater and industrial wastewater flows to the Picton STS	The licensee is required to undertake source control investigations to reduce stormwater and industrial wastewater flows to the Picton sewage treatment system.	02-May-2019
Pollution Study: Investigations for additional wastewater recycling and reuse options for Picton sewage treatment system	The licensee is required to undertake investigations to identify opportunities for additional wastewater recycling and reuse options for Picton sewage treatment system	31-December-2018
Pollution Study: Trial pilot-scale constructed wetlands project	To require the licensee to undertake a trial pilot-scale constructed wetland(s) project at the Picton STP to assess the treatment performance, effectiveness and cost of these wetlands in reducing pollutant concentration levels in the treated wastewater discharges.	17-August-2018

8 Pollution Studies and Reduction Programs

U1 Pollution Study 308: Dry weather overflow abatement program 2025-2029

- U1.1 **308.1** The objectives of this Pollution Study are to require the licensee to develop and submit a Sydney Water area of operations wide program of works for dry weather overflow (DWO) abatement in the 2025-2029 IPART price period which:
- targets reductions in both the frequency and volume of DWOs in areas where DWOs are likely to have a comparatively high environmental and/or human health impact; and
 - in the interests of attaining continuous improvement in sewage treatment system environmental performance, aims to achieve demonstrable improvement in the licensee's DWO environmental performance beyond its existing performance at 30 June 2025.
- U1.2 **308.2** The licensee must develop and submit in writing to the EPA by 2 December 2022 a report presenting a proposed Sydney Water area of operations wide program of works for DWO abatement in the 2025-2029 IPART price period which:
- targets reductions in both the frequency and volume of DWOs in areas where DWOs are likely to have a comparatively high environmental and/or human health impact, by prioritising works based on consideration of a range of factors, including but not needing to be limited to:
 - the likelihood of DWOs occurring.
 - the likely volume of DWOs when they occur.
 - the sensitivity, ecological value and public use of the receiving environment.
 - the level of difficulty of access for response and clean-up of DWOs when they occur.

Environment Protection Licence

Licence - 10555

- b) is based on consideration of a wide range of cost-effective contemporary, innovative and emerging DWO abatement methods, techniques and technologies with reference to Australian and international DWO abatement best practice;
- c) aims to achieve demonstrable improvement in the licensee's DWO environmental performance beyond its existing performance at 30 June 2025; and
- d) includes:
 - i. a detailed description of the approach (including but not needing to be limited to an outline of the data, information and analyses) used to prioritise the areas selected for abatement based on condition 308.2a).
 - ii. a description of the program of works, including (but not needing to be limited to): a description of the types of works; the areas to be abated; and the scale/amount of works to be implemented.
 - iii. the rationale for the program of works, including (but not needing to be limited to) justification for the selection of: the types of works; the areas to be abated; and the scale/amount of works to be implemented.
 - iv. An estimated breakdown of the schedule of works for each financial year in the period 2025-2029.
 - v. the estimated costs of the works for each financial year in the period 2025-2029.
 - vi. an assessment of the expected benefits of the program of works in terms of (but not needing to be limited to) quantified estimated reductions in the frequency and volume of DWOs.
 - vii. (in line with condition 308.1b) a quantified assessment of how the program is expected to result in improved DWO environmental performance beyond the licensee's existing performance at 30 June 2025.

U1.3 308.3 The licensee must finalise the draft program of works by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such comments.

Note: A Pollution Reduction Program is intended to be included on the licence for implementation of dry weather overflow abatement works in 2025-2029 based on the outcomes of this Pollution Study.

U2 Pollution Study: Waterway health monitoring and adaptive management

U2.1 The objective of this pollution study is to design a program which:

- Provides an ongoing assessment of the potential environmental and human health impacts on Stonequarry Creek and the Hawkesbury Nepean River posed by the discharge of treated effluent to Stonequarry Creek from the premises.
- Informs an adaptive management process to minimise water pollution and impacts to the environment and human health.

U2.2 By 26 June 2023 the licensee must submit to the EPA for comment, a draft project plan that outlines the process to be undertaken by the licensee to meet the objectives stated in U2.1 and develop the draft monitoring plan specified in condition U2.4.

U2.3 The licensee must finalise the draft project plan required for U2.2 by addressing all written comments provided by the EPA, then resubmitting it to the EPA within four weeks of receiving such comments.

U2.4 By 26 November 2023 the licensee must submit to the EPA for comment and approval, a draft monitoring

Environment Protection Licence

Licence - 10555

plan for the project the meets the objectives stated in U2.1. The monitoring program plan must clearly outline the following:

- the program scope, tasks, methodology, timeframes and reporting requirements.
- how an appropriate baseline will be established.
- the projected outcomes.
- thresholds for identifying the threat of serious or irreversible damage to the environment.
- the process that Sydney Water will follow in response to threshold exceedances and/or outcomes not consistent with projected outcomes.
- how Sydney Water will evaluate the ongoing success of this program.

U2.5 The licensee must finalise the draft monitoring plan required for U2.4 by addressing all written comments provided by the EPA on the monitoring plan, then resubmitting it to the EPA within four weeks of receiving such comments.

U2.6 By 26 June 2023 the licensee must provide a report which demonstrates the accuracy of the Point 10 flow monitoring gauge. The report must include the following:

- Information on how the flow gauge measures and reports flow in Stonequarry Creek.
- Information on the method undertaken to calibrate the flow gauge.
- Conclusions about the accuracy of the flow monitoring gauge.
- Statistical analysis to support conclusions.
- Recommendations (if any) to improve the accuracy of the flow monitoring gauge.

Note: Note: Additional conditions may be included on the licence for implementation of the project following finalisation of the project plan and/or monitoring program plan.

U3 Pollution Study: Macroalgae trial detailed assessment

U3.1 The objectives of this Pollution Study are to require the licensee to conduct a detailed investigation to assess the macroalgae treatment trial project currently being undertaken at the Picton STP compared with other treatment technologies including the onsite wetlands. The investigation findings will inform consideration of the feasibility of implementing larger scale macroalgae treatment at the Picton STP and/or at the licensee's other STPs.

U3.2 By 26 June 2023, the licensee must develop and submit to the EPA, a draft project plan for the project that allows the licensee to meet the objective stated in condition U3.1 including:

- assessment of treatment performance and effectiveness in reducing pollutant concentration levels in the treated effluent discharges produced at Picton STP and discharged to Stonequarry Creek and the Hawkesbury-Nepean River system;
- assessment of effectiveness in reducing total phosphorus concentrations to meet the 50th percentile concentration limit of 0.1 mg/L which is due to apply from 1 July 2024;

Environment Protection Licence

Licence - 10555

- comparison of the macroalgae trial to other macroalgae treatment options; and
- comparison of the macroalgae treatment to other treatment technologies including the onsite wetlands.

The project plan should clearly outline (and provide justification where applicable):

- i. the project background and scope;
- ii. the options analysis of all macroalgae considered for this project and the justification for the preferred option(s) to be trialled;
- iii. key tasks and deliverables in relation to the operation of the macroalgae trial;
- iv. an outline of the assessments, methodologies (e.g. monitoring), data, information and analyses required for the investigation;
- v. project timeframes for the tasks required to complete this Pollution Study and key project milestones; and
- vi. the process / analysis required for potentially applying the findings of this trial to larger scale treatment at the Picton STP and/or at the licensee's other STPs.

U3.3 The licensee must finalise the project plan by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

U3.4 26 November 2023, the licensee must undertake the investigations in accordance with the objective and scope outlined in conditions U3.1 and U3.2 and the methodology and timelines in the EPA approved project plan (or any revisions to the project plan approved by the EPA in writing) and submit a detailed draft report on the investigations to the EPA which must include (but not be limited to):

- An introduction and background.
- Description of assumptions and limitations of the investigation.
- Detailed assessment, analysis and discussion of monitoring results.
- Results and discussion of comparison to alternative macroalgae treatment and other alternative treatment.
- Identification and options assessment for all feasible alternatives.
- Discussion on feasibility and viability of upscaling the macroalgae treatment.
- Recommendations and conclusions.

U3.5 The licensee must finalise the draft report by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

Note: A further Pollution Study and/or Reduction Program may be included on the licence for implementation of the trial project following finalisation of the project plan and/or draft report.

U4 Pollution Study: Investigation into reducing phosphorus concentrations

U4.1 The objective of this Pollution Study is to require the licensee to undertake a detailed investigation into the options for reducing the concentrations of total phosphorus to comply with the Hawkesbury Nepean Nutrient Framework condition L3.5 due to commence on 1 July 2024.

U4.2 By 26 November 2023 the licensee must investigate and consider all options to reduce total phosphorus concentrations and fulfil the objective at condition U4.1. The scope of these investigations must include (but

Environment Protection Licence

Licence - 10555

not be limited to) the following:

- Current industry best practice technology for the reduction of total phosphorus concentrations.
- The consideration of site-specific constraints.

The licensee must assess all options to reduce total phosphorus concentrations. The options assessment must, as a minimum:

- consider the range of feasible options, including both long-term and short-term options (<10 years);
- recommend the preferred options(s) that will reduce the total phosphorus concentrations to a maximum of 0.1mg/L (50th percentile);
- provide adequate justification for the preferred options(s) by a cost/predicted benefit analysis; and
- provide a timeframe for the implementation of the preferred option(s).

U4.3 By 26 November 2023, the licensee must submit a draft report to the EPA that, at minimum fulfils the requirements of Conditions U4.1 and U4.2.

U4.4 The licensee must finalise the draft report by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

Note: Note: A Pollution Reduction Program may be included on the licence for implementation of works based on the outcomes of this Pollution Study.

U5 Pollution Study: Investigation to reduce inflows

U5.1 The objective of this Pollution Study is to require the licensee to undertake detailed investigation to identify opportunities for reducing inflows into the premises. This is to inform decisions about undertaking works to reduce Picton STP effluent discharges to Stonequarry Creek and the Hawkesbury-Nepean river system.

U5.2 By 26 June 2023, the licensee is to develop and submit to the EPA, a project plan for the Pollution Study that meets the objectives stated in U5.1 and clearly outlines the project tasks, scope, methodology, timeframes, reporting and review. The project plan should outline the data and information that Sydney Water proposes to review as part of this Pollution Study.

U5.3 The licensee must finalise the project plan by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

Note: Note: A Pollution Reduction Program may be included on the licence for implementation of works based on the outcomes of this Pollution Study

Environment Protection Licence

Licence - 10555

U6 Pollution Reduction Program: Reduce pollutant concentrations and loads

- U6.1 The objective of this Pollution Reduction Program is to design, assess and implement a proposal to reduce the concentrations and loads of pollutants discharged by the Picton STP through the following means:
- large-scale wetlands;
 - irrigation of additional landscaped areas on the Picton STP site; and
 - additional treatment for flows transferred from the Eastern Dam to Western Dam to be compliant with condition O4.1.
- U6.2 By 26 June 2023, the licensee must develop a draft project plan for each of the projects that allows the licensee to meet the objective stated in condition U6.1 and which clearly outlines (and provides justification where applicable):
- (i) the project background and scope;
 - (ii) project objectives;
 - (iii) the options analysis of all options considered for this project and the justification for the preferred option(s) to be undertaken;
 - (iv) key tasks and deliverables in relation to the construction and operation of the selected options;
 - (v) an outline of the assessments, methodologies (e.g. monitoring), data, information and analyses required to evaluate the success at achieving the objective at U6.1;
 - (vi) project timeframes for the tasks required to complete this Pollution Reduction Program and key project milestones.
- U6.3 The licensee must finalise the project plan by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

U7 Pollution Study: Investigation into managing effluent

- U7.1 The objective of this Pollution Study is to require the licensee to undertake a detailed investigation to identify opportunities for additional recycling and reuse of treated effluent from the premises This is to inform decisions about increasing off-site recycling and reuse of treated effluent from the premises to reduce the frequency and volume of discharges of treated effluent from the Picton STP into Stonequarry Creek and the Hawkesbury-Nepean river system.
- The EPA may utilise the information provided under this Pollution Study to include additional conditions in this EPL.
- U7.2 By 26 June 2023, the licensee must develop and submit to the EPA, a draft plan for the study that allows the licensee to meet the objective stated in condition U6.1 and which clearly outlines (and provides justification where applicable):
- (i) the project background and scope;
 - (ii) the options analysis of all options considered for this project and the justification for the preferred option(s) to be undertaken;
 - (iii) key tasks and deliverables in relation to the construction and operation of the selected options;
 - (iv) an outline of the assessments, methodologies (e.g. monitoring), data, information and analyses required to evaluate the success at achieving the objective at U6.1;

Environment Protection Licence

Licence - 10555

- (v) the process for providing regular progress reports to the EPA;
- (vi) project timeframes for the tasks required to complete this Pollution Reduction Program and key project milestones.

The scope of these investigations must include (but not be limited to) the following options for reuse and recycling of treated effluent from the premises:

- Investigating onsite reuse (options not included in in Pollution Reduction Program U6 “*Reduce pollutant concentrations and loads*”).
- Investigating offsite reuse including Wollondilly Shire Council sites, small rural properties, new developments, consideration of recycled water pipeline.
- Smart irrigation technology.

U7.3 The licensee must finalise the project plan by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.

U8 Pollution Study: assessment of extreme wet weather discharges

- U8.1 The objective of this Pollution Study is to assess the suitability of the rainfall forecast trigger volume specified in condition L4.3 b) in managing incoming sewage during extreme wet weather events and the associated risk of dam spills.
- U8.2 By 26 June 2023. The licensee is to develop and submit to the EPA, a project plan for the Pollution Study which meets the objectives stated in U8.1 and clearly outlines the project tasks, scope, methodology, timeframes, reporting and review. The project plan should outline the data and information that Sydney Water proposes to review as part of this Pollution Study.
- U8.3 The licensee must finalise the project plan by addressing any written comments provided by the EPA and resubmit it to the EPA within four weeks of receiving such comments.
- U8.4 From 1 July 2023 to 30 June 2025 the licensee must record the following for anticipated extreme wet weather discharges:
- The capacity in the Eastern Dam at the start and finish of discharge.
 - The capacity in the Western Dam at the start and finish of discharge.
 - The start and finish date/time of discharge, and the total volume discharged during that time.
 - For each day of anticipated extreme wet weather event discharges, the five-day rainfall volume weather forecast reported by the Bureau of Meteorology at the Camden weather station (ID 9755).
 - For each day of anticipated extreme wet weather event discharges, the amount of daily rainfall measured at a rain gauge at the STP.
 - The amount of daily rainfall at the rain gauge closest to the centre of the catchment of the sewage system.

Environment Protection Licence

Licence - 10555

- If any other effluent disposal (such as irrigation or reuse) is occurring whilst discharge occurs, the type, volume and source of each.
- The start and finish date/time, and total volume spilled for any spills that occur from the Eastern Dam.
- The start and finish date/time, and total volume spilled for any spills that occur from the Western Dam.

Note: Additional conditions may be included on the licence for implementation of the project following finalisation of the project plan.

U9 Pollution Study 309: Development of choke prioritisation methodologies to produce choke improvement prioritisation lists

U9.1 Pollution Study 309.1: Development of a choke prioritisation methodology for the purpose of producing a choke improvement prioritisation list - Improvement period 2025 - 2030

- a) The objective of this Pollution Study is to require the Licensee to develop a choke prioritisation methodology, through the identification, development and use of appropriate tools and information, for use across all of the Licensees areas of operations in the choke improvement period 2025 – 2030.
- b) The licensee must develop and submit in writing to the EPA by 30 June 2024 a draft choke prioritisation methodology which takes into account the likelihood and consequence of chokes occurring in a given area.
- c) The licensee must finalise the draft choke prioritisation methodology by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such comments.
- d) The licensee must host at least two progress workshops with the EPA throughout the development of the choke prioritisation methodology.

U9.2 Pollution Study 309.2: Refinement of the choke prioritisation methodology for the purpose of producing an improved choke improvement prioritisation list - Improvement period 2030 - 2035

- a) The objective of this Pollution Study is to require the Licensee to improve the choke prioritisation methodology developed under Pollution Study 309.1, through the identification, development and use of appropriate tools and information, for use across all of the Licensees areas of operations in the choke improvement period 2030 – 2035.
- b) The licensee must develop and submit in writing to the EPA by 30 June 2027 an improved choke prioritisation methodology which takes into account the likelihood and consequence of chokes occurring in a given area.
- c) The licensee must finalise the draft improved choke prioritisation methodology by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such

Environment Protection Licence

Licence - 10555

comments.

d) Starting from the 2024-25 financial year, the licensee must host at least two progress workshops with the EPA throughout the development of the improved choke prioritisation methodology.

U10 PRP 308: Choke Improvement Pollution Reduction Program

U10.1 PRP 308.1: Choke Improvement Pollution Reduction Program – Improvement period 2025 - 2030

Note: The details of this PRP are to be determined following submission by the licensee of the choke improvement prioritisation list as required by condition L7.5a) before 31 December 2024.

U10.2 PRP 308.2: Choke Improvement Pollution Reduction Program – Improvement period 2030 - 2035

Note: The details of this PRP are to be determined following submission by the licensee of the choke improvement prioritisation list as required by condition L7.5a) before 31 December 2027.

9 Special Conditions

E1 Sydney Water Dry Weather Sewage Overflow Response Report

E1.1 Report Scope

a) The Licensee must provide a single, combined Report (“the Report”) on the adequacy of the systems, resources, processes, procedures, practices and training it has in place for its reticulation system as at the date which this condition is included in the Licence to comply with:

1. Condition O3.1 of the Sydney Water Environment Protection Licences (EPLs) on responding to sewer overflows; and
2. Part 5.7 of the Protection of Environment Operations Act 1997 (“the Act”) regarding the notification of incidents; and
3. Part 5.7A of the Act and Part 3A POEO (General) Regulation regarding requirements for a Pollution Incident Response Management Plan (PIRMP).

b) The Report is to identify any improvements that the Licensee should make so that its response to sewer overflows from its reticulation system complies with the regulatory requirements identified within this condition.

E1.2 Independent Expert

a) The Report must be prepared by a suitably qualified and experienced independent environmental expert (the “Expert”).

Environment Protection Licence

Licence - 10555

b) Details of three options on the Expert (and team members) proposed to be engaged by the Licensee must be provided to the EPA's Regional Manager Operations - Metropolitan Infrastructure for written approval by 12 April 2019.

c) The Licensee must ensure when selecting the proposed Expert and their team for b) above that there is expertise in each team across all the areas of human health, aquatic and terrestrial ecology, water science, laboratory operations, sewage and environmental engineering, logistics and systems auditing. For the purposes of this condition, the Licensee must provide the EPA the following details for the Expert and each proposed team member:

1. name;
2. contact details;
3. the area in which they have expertise;
4. relevant qualifications;
5. relevant experience;
6. availability.

d) The Licensee must engage an Expert and team that is approved by the EPA's Regional Manager Operations - Metropolitan Infrastructure in writing by two weeks after approval is received from the EPA.

e) Once engaged, the Licensee must require the Expert and their team to meet with the EPA to discuss the background and context for the Report.

E1.3 Report Requirements

a) The Licensee must provide a single combined Report which examines, makes recommendations to improve and provides conclusions about the effectiveness of the licensee's procedures and processes with respect to its response to sewer overflows from its reticulation system.

b) The Report must detail the current systems, resources, processes, procedures, practices and training used by the Licensee on or around the time that this condition was included in this Licence.

c) The Licensee must also require the Expert to provide as part of the final Report:

1. a list of all the documents considered, including copies of any of the Licensee's procedures specifically referenced in the Report;
2. names, roles and organisations of personnel interviewed by the Expert (including their team members) in preparing the Report.

d) The report must consider the following:

E1.4 Notifications

a. process for notification of incidents to the EPA to meet the requirements of Part 5.7 of the Act;

b. process for determining incidents that trigger the statutory requirement for notification to the EPA per Part 5.7 of the Act;

c. process for providing information to comply with Part 5.7 of the Act;

d. process for providing further information to the EPA following the initial self-report in an accurate and timely manner to comply with Part 5.7 of the Act;

e. the practices used to implement the processes under a – d in a timely and consistent manner;

Environment Protection Licence

Licence - 10555

E1.5 *Incident Management*

- f. roles and responsibilities of personnel involved in incident management including, but not limited to, overseeing of incident response, coordination and implementation of on ground response, liaison with and communication to the EPA, provision of information to the public, and whether roles and responsibilities are sufficiently clear;
- g. availability, accessibility and scheduling of suitable plant and personnel resources for all aspects of managing the sewer overflow;
- h. process and methodology used to allocate priority when responding to sewer overflows, including relationships to other responses being undertaken by the Licensee;
- i. whether the systems, resources, processes, procedures, practices and training in place for monitoring and auditing current processes require improvement and if so, the reasons, to meet the requirements of Condition O3.1 of the EPLs;

E1.6 *Rectification of faults and sewage containment*

- j. processes or procedures for response to, and rectification of, faults;
- k. adequacy of processes and procedures for achieving timely and satisfactory fault rectification;
- l. processes or procedures for implementation of sewage containment strategies;
- m. adequacy of processes and procedures for achieving timely implementation of sewage containment strategies;
- n. adequacy and effectiveness of the methods for, and execution of, sewage containment, to meet the requirements of Condition O3.1 of the EPLs;

E1.7 *Management of environmental and health impacts resulting from sewer overflows*

- o. assessment methodology for determining environmental and health impacts resulting from sewer overflows;
- p. assessment methodology for determining appropriate clean-up strategies to remediate the environment and reduce risk to public health;
- q. processes or procedures for achieving timely implementation of clean-up strategies;
- r. types of environmental remediation works utilised to clean-up after sewer overflows;
- s. effectiveness of environmental remediation works utilised to clean-up after sewer overflows;
- t. types of remediation works utilised for reducing public health risks from sewer overflows;
- u. effectiveness of remediation works utilised for reducing public health risks from sewer overflows;
- v. assessment methodology for determining the adequacy of clean-up strategies; and
- w. environmental impact of clean-up strategies, to meet the requirements of Condition O3.1 of the EPLs;

E1.8 *Risk communication*

- x. methods used to communicate potential health risks from sewer overflows to potentially affected parties to meet the requirements of Condition O3.1 of the EPLs. This may include but is not limited to signage, door knocking, written notification and physical barriers;
- y. processes for achieving timely implementation of communication referred to in (x) to meet the requirements of Condition O3.1 of the EPLs;
- z. adequacy and appropriateness of communication methods deployed; and

E1.9 *Training*

- aa. adequacy of the Licences' requirements for staff competency in relation to incident management, fault

Environment Protection Licence

Licence - 10555

rectification, assessment of environmental and health risks and undertaking remediation works, including staff training provided by the Licensee.

E1.10 Report

- a) The Licensee must submit to the EPA's Regional Manager Operations - Metropolitan Infrastructure a draft Report ("Draft Report"), being a report prepared by the Expert (and their team) covering all of the matters described in conditions E1.3-E1.9, six months after the Expert is engaged (condition E1.2 d).
- b) The Licensee must ensure the Draft Report is updated to address any comments made by the EPA.
- c) The Licensee must submit to the EPA's Regional Manager Operations - Metropolitan Infrastructure the final Report one month after the EPA's comments have been provided (condition E1.10 b).

E1.11 Implementation of the Report Recommendations

- a) The Licensee must submit an Implementation Plan to the EPA's Regional Manager Operations - Metropolitan Infrastructure by no later than three months after acceptance of the final Report by the EPA (condition E1.10 c).
- b) The Implementation Plan must:
 1. identify what actions the Licensee proposes to take in response to the Report from the Expert;
 2. propose a timeframe for these action(s); and
 3. provide an explanation for the Licensee's proposals where there is any variance from the recommendations in the final Report.

- E1.12 a) The Licensee must complete all activities and outputs identified in Appendix 1 of the Implementation Plan dated 22 November 2020 by 30 June 2022.
- b) Evidence of the completion of the Implementation Plan activities and outputs must be provided to the EPA as outlined in Condition E1.13b.

E1.13 Progress Report

- a) The Licensee must submit a Progress Report to the EPA's Manager Regulatory Operations Metro every three months from 25 October 2021 detailing the progress of all activities and outputs to be implemented in accordance with the Implementation Plan until all activities and outputs have been completed.
- b) Each Progress Report outlined in condition E1.13a must:
 1. Provide a status update on activities and outputs to achieve the recommendations identified in Appendix 1 of the Implementation Plan that have been completed since the last Progress Report; and
 2. Outline any work packages that will not be completed by June 2022, including the details of any reasons why the Licensee has been unable to complete these work packages.

Environment Protection Licence

Licence - 10555

E2 Mandatory Environmental Audit

E2.1 Audit purpose

Subject to conditions E2.2 - E2.20 below, the licensee must engage an auditor to undertake a mandatory environmental audit ("the Audit"). The purpose of the Audit is to:

- a) provide information to the licensee about the adequacy of its systems to comply with regulatory requirements including compliance with the Act and licence conditions in order to:
 - prevent the occurrence of sewage overflows from rising mains and minimise the community and environmental health risks posed by these sewage overflows;
 - prevent the occurrence of sewage overflows from sewage pumping stations caused by failure and minimise the community and environmental health risks posed by these sewage overflows; and
- b) identify improvements to be made by the licensee so that the licensee's systems in place for managing sewage pumping stations and rising mains comply with the regulatory requirements including under the Act and licence conditions.

E2.2 Independent Auditor

The licensee must engage a suitably qualified and experienced independent certified environmental auditor (the "Auditor"). The Auditor may obtain the services of additional Auditor/s and relevant technical experts. At a minimum, the Auditor and team members must comprise of expertise in the areas of sewage and environmental engineering, logistics and systems auditing. It is noted that the EPA encourages the licensee to consider relevant international as well as national expertise. The Auditor and team members must be approved of in writing by the EPA before being engaged.

E2.3 By 2 December 2022, the licensee must provide the EPA by email addressed as "ATTENTION Manager ROMS" to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, with the details of at least three Auditors (and team members) that are suitably qualified to undertake the Audit under condition E2.6 - E2.14. The licensee may identify a preferred Auditor and team to undertake the Audit. For the purposes of this condition, the licensee must provide the EPA with the following details for the Auditor and each proposed team member:

- name;
- contact details;
- the area in which they have expertise;
- relevant qualifications;
- relevant experience; and
- availability.

E2.4 The EPA will approve an Auditor and team and advise the licensee in writing. The licensee must engage the approved Auditor team within two weeks after the EPA's approval.

E2.5 Within five weeks of engagement of the Auditor and team, the licensee must arrange for the Auditor and their

Environment Protection Licence

Licence - 10555

team to meet with the EPA to discuss the background and context for the Audit.

Audit Scope

- E2.6 The requirement to prepare an audit in relation to this licence can be satisfied by the licensee providing a single combined report that addresses issues relevant to each of the 23 licences the subject of these mandatory audit requirements.
- E2.7 In relation to systems currently in place for managing and operating sewage pumping stations and rising mains, the Audit must:
- detail and examine those systems and the licensee's adherence to those systems;
 - detail and examine any deficiencies in those systems and the licensee's adherence to those systems; and
 - make recommendations and conclusions in respect of the following (E2.8 - E2.14), without limitation:
- E2.8 *Construction and design*
- a. systems for considering the following in the construction and design of new upgraded or replacement sewage pumping stations and rising mains:
 - i. locational, environmental, and operational risk factors, including capacity of pumping stations and rising mains to account for future state planning needs;
 - ii. future maintenance and resource requirements;
 - iii. redundancy;
 - b. systems for ensuring the construction and design of new, upgraded or replacement sewage pumping stations and rising mains comply with relevant design and construction standards;
 - c. systems for ensuring quality control and quality assurance for new, upgraded or replacement sewage pumping stations and rising mains to comply with relevant standards;
 - d. adequacy of the systems in place for constructing and designing new, upgraded or replacement sewage pumping stations and rising mains including those at a.- c. to meet the regulatory requirements at condition E2.1.
 - e. adequacy of the systems in place for constructing and designing new, upgraded or replacement sewage pumping stations and rising mains including those at a.- c. to meet best international practice, codes of practice and relevant policies relating to the protection of the environment and human health.
- E2.9 *Operation*
- f. the licensee's requirements for staff competency in relation to operating rising mains and pumping stations, including staff training by the licensee;
 - g. adequacy of the systems for operating sewage pumping stations and rising mains in a manner which reduces risk factors related to failure, prevents the occurrence of sewage overflows and minimises the human health and environmental impact of resultant sewage overflows;
 - h. adequacy of the systems for operating sewage pumping stations and rising mains to meet the regulatory requirements at condition E2.1;
 - i. adequacy of the operating systems for sewage pumping stations and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment and human health.

Environment Protection Licence

Licence - 10555

E2.10 *Assessment of condition*

- j. systems for identifying the need to undertake condition assessment for sewage pumping stations and rising mains including methodology, timeliness, frequency, resource and financial allocation towards condition assessment and amongst different condition assessment activities;
- k. systems for planning and scheduling for short, medium and long term condition assessment for sewage pumping stations and rising mains including methodology, timeliness, frequency and, resource and financial allocation at the level of the officer staff overseeing condition assessment activities and at the business level of staff overseeing remedial activities, resource supply and, financial allocation;
- l. systems for undertaking condition assessment of rising mains and sewage pumping stations including methodology, timeliness, frequency and, resource and financial allocation;
- m. technology and techniques used to undertake condition assessment;
- n. systems to develop better technology and improved techniques to undertake condition assessment on sewage pumping stations and rising mains;
- o. systems for planning and undertaking of follow-up actions for sewage pumping stations and rising mains when condition assessment results are received, in particular what processes are followed when a condition assessment identifies recommendations, makes conclusions or proposes improvements or identifies that risk of failure factors have changed;
- p. systems for prioritising assessment of condition activities against both:
 - other rising main and sewage pumping station assets; and
 - other licensee plant systems and works;
- q. adequacy of the systems, technology and techniques including those at j.-p. for undertaking condition assessment for rising mains and pumping stations to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;
- r. adequacy of the systems, technology and techniques including those at j.-p. for undertaking condition assessment for rising mains and pumping stations to meet the regulatory requirements at condition E2.1.
- s. adequacy of the systems, technology and techniques at j.-p. for condition assessment of rising mains and pumping stations to meet best international practice, codes of practice and relevant policies relating to the protection of the environment.

E2.11 *Remedial activities*

- t. systems for identifying remedial activities needs including methodology, timeliness, frequency and, resource and financial allocation;
- u. systems for planning and scheduling for short, medium and long term remedial activities for sewage pumping stations and rising mains including methodology, timeliness, frequency and, resource allocation, at the level of the officer staff overseeing remedial activities and at the business level of staff overseeing remedial activities, resource supply and, financial allocation;
- v. systems for undertaking remedial activities including methodology, technology, timeliness, frequency and, resource and financial allocation;
- w. technology and techniques used to undertake remedial activities for sewage pumping stations and rising mains;
- x. systems to develop better technology and improved techniques to undertake remedial activities on sewage pumping stations and rising mains;
- y. systems for considering all relevant risk factors related to failure of sewage pumping stations and rising mains in identifying and undertaking remedial activities;
- z. systems for prioritising remedial activities for rising mains and sewage pumping stations against both:
 - other rising main and sewage pumping station assets; and

Environment Protection Licence

Licence - 10555

- other licensee plant systems and works;
 - aa. systems for updating remedial schedules and plans when relevant and new or previously unaccounted for information is identified;
 - bb. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;
 - cc. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to meet the regulatory requirements at condition E2.1.
 - dd. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to meet best international practice, codes of practice and relevant policies relating to the protection of the environment.

E2.12 Contingency planning and response

- ee. the systems for contingency planning and response to prevent a sewage overflow after failure occurs for sewage pumping stations and rising mains including:
 - i. the timeliness and availability of resources and information about contingency planning and response;
 - ii. the licensee's requirements for staff competency in relation to responding to failures of rising mains and pumping stations, including staff training by the licensee;
- ff. after a sewage overflow occurs from a sewage pumping station or rising main, the systems for contingency planning and response to minimise the volume of sewage discharged to the environment and minimise environmental/human health impacts including:
 - i. the timeliness and availability of resources and information about contingency planning and response;
 - ii. the licensee's requirements for staff competency in relation to responding to failures of rising mains and sewage pumping stations, including staff training by the licensee;
- gg. the systems for contingency planning before failure occurs in a sewage pumping station and rising main to:
 - i. identify risk factors;
 - ii. identify asset failure scenarios;
 - iii. test and update plans;
- hh. the adequacy of systems for contingency planning and response to prevent a sewage overflow after failure occurs for sewage pumping stations and rising mains to meet the regulatory requirements at condition E2.1;
 - ii. the adequacy of systems for contingency planning and response to minimise the volume of sewage discharged to the environment and minimise environmental/human health impacts after a sewage overflow from a sewage pumping station or rising main occurs, to meet the regulatory requirements at condition E2.1;
- jj. the adequacy of systems for contingency planning before failure occurs in a sewage pumping station or rising main to meet the regulatory requirements at condition E2.1;
- kk. the adequacy of systems for contingency planning and response to prevent a sewage overflow after failure occurs in sewage pumping stations and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment;
- ll. the adequacy of systems for contingency planning and response to minimise the volume of sewage discharge to the environment and minimise environment and human health impacts after a sewage overflow occurs from a sewage pumping station and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment
- mm. the adequacy of systems for contingency planning before failure occurs or issue arises in a sewage pumping station or rising main to meet best international practice, codes of practice and relevant policies

Environment Protection Licence

Licence - 10555

relating to the protection of the environment.

E2.13 *Risk assessment and risk management*

- nn. the systems to undertake risk assessment/s including methodology, data sources and significance weightings given to components of the risk assessment to determine and manage the risk and consequence of failure;
- oo. the systems to review and update risk assessment/s including methodology, data sources, frequency and timeliness;
- pp. the systems for using risk assessment information for contingency planning
- qq. the systems for implementing action to mitigate risks;
- rr. the adequacy of the risk assessment systems including those at nn.-qq. to account for all relevant risk factors which could contribute to failure including (but not limited to) infrastructure characteristics, sewage characteristics, environmental conditions, locational, redundancy, accessibility and operational risk factors;
- ss. adequacy of risk assessment and risk management systems including those at nn.-qq. to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;
- tt. adequacy of risk assessment and risk management systems including those at nn.-qq. for rising mains and sewage pumping stations to meet the regulatory requirements at condition E2.1;
- uu. the adequacy of risk assessment/s process to enable the licensee to prioritise and make decisions about rising main and sewage pumping station condition assessment and remedial activities.

E2.14 *Recommendations*

- vv. Recommendations for any improvements that the licensee should make so that its rising mains and pumping stations are operated and managed:
 - i. in accordance with best international practice and best available technology;
 - ii. in a manner which prevents future rising main and sewage pumping station failures and resultant sewage overflows;
 - iii. in a manner so that they are not carried on in an environmentally unsatisfactory manner;
 - iv. in order to meet the regulatory requirements at condition E2.1.
- ww. Recommendations for a broad strategic plan that the licensee should undertake for improvements made under vv., in time frames of less than 5 years, 10 years, 20 years and 30 years plus.

Environmental Audit Report Requirements

- E2.15 The licensee must instruct the Auditor to prepare a draft environmental audit report ("Draft Audit Report"), being a single, combined report prepared by the Auditor, which includes:
 - a) all of the matters described in conditions E2.1, E2.6 and E2.7 - E2.14;
 - b) a list of documents considered and reviewed, including any of the licensee procedures specifically referenced in the Draft Audit Report;
 - c) names, roles and organisations of personnel interviewed by the Auditor (including their team members) in preparing the Draft Audit Report;
 - d) the two declarations required under Section 176 of the Act; and
 - e) a summary of the Audit including the conclusions and recommendations, in electronic format so it can be entered into the Public Register (as required by section 308 of the POEO Act).

Environment Protection Licence

Licence - 10555

- E2.16 The licensee must instruct the Auditor to provide the Draft Audit Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, within 6 months of the date of the EPA’s written approval of the Auditor and at the same time as, or before, the Draft Audit Report is provided to the licensee.
- E2.17 The licensee must ensure the Draft Audit Report is updated by the Auditor to address any comments made by the EPA.
- E2.18 The licensee must submit the Final Audit Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, no later than one month after receipt of the EPA’s comments on the Draft Audit Report. A PDF version of the report is to be provided.

Implementation of Recommendations of Mandatory Environmental Audit

- E2.19 The licensee must submit an Audit Implementation Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, by no later than 3 months after receipt of the Final Audit Report.
- E2.20 The Audit Implementation Report must:
- identify what actions the licensee proposes to take in response to the Audit Report;
 - propose a timeframe for these action(s); and
 - provide an explanation for the licensee’s proposals where there is any variance from the recommendations of the Auditor in the Final Auditor Report.

E2.21 Mandatory Environmental Audit Dictionary

For the purposes of conditions E2.1 to E2.20 the following definitions apply:

Rising main means:

a sewer pressure main which transfers sewage collected by sewage pumping station to a point of discharge such as a gravity sewer main or sewage treatment plant between the last valve inside a pumping station site and the discharge point.

Sewage pumping station means:

a structure which controls the transport of sewage through the sewer pipes, where steep hills and other variations in the land topography can prevent or limit the gravity flow of sewage to the sewage treatment plant. The sewage pumping station includes infrastructure from the collecting manhole to the start of the rising main and all infrastructure relevant to the function of the sewage pumping station.

Environmentally unsatisfactory manner means:

the definition as specified in section 95 of the Act.

Systems means:



Environment Protection Licence

Licence - 10555

the licensee’s interacting or interdependent policies, plans, procedures, practices, processes, standards, strategies and resources (not limited to those) which are currently in place for managing and operating sewage pumping stations and rising mains.

Condition assessment means:
activities undertaken for the purpose of determining the condition of an asset. This includes (but is not limited to) activities undertaken to identify whether there are any leaks or defects on an asset, activities undertaken to determine how much life the asset has left, and activities to decide upon preventative maintenance or remedial work to extend its life or replacement of the asset.

Remedial activities means:
activities related to maintenance, repair, renewal, upgrade and redundancy upgrades.

Failure means:
an issue which inhibits or prevents normal operation of a sewage pumping station or rising main which could lead to sewage overflows.

E3 Long Term Solution

- E3.1 The licensee must undertake the planning and preparation necessary to cease all discharges of effluent from the sewage treatment plant to Stonequarry Creek by 31 December 2032.
- E3.2 The licensee must provide the EPA with yearly updates on its progress towards meeting condition E3.1.
- E3.3 Progress updates must be emailed to the EPA and addressed to “ATTENTION Manager ROMS” provided to info@epa.nsw.gov.au and copies to metrowater.infrastructure@epa.nsw.gov.au.

E4 Special Dictionary

E4.1

Term	Definition
approved	Means approved in writing by the EPA. The EPA’s approval may be given unconditionally, or subject to conditions.
average concentration limit	Means the average of twelve monitoring test results undertaken during the reporting period.
average dry weather flow (ADWF)	Means the average flow at a point calculated or measured over a 24 hour period in dry weather.
Biosolids	Has the same meaning as in Schedule 1, Part 3 of the Protection of the Environment Operations Act 1997.

Environment Protection Licence

Licence - 10555

Biosolids Guidelines	Means the “Environmental Guidelines: Use and disposal of biosolids products” published by the EPA November 1997, or any subsequently updated guidelines which replace this publication.
Bypass	Means circumstances where sewage has been received at the sewage treatment plant but is discharged from the plant without it being treated, processed or reprocessed by means of any or all of the designed treatment processes of the plant. A new bypass event is defined as a bypass that commences at least 24 hours after the end of the previous bypass.
catchment	Catchment boundaries are marked on the system map.
cfu	Means colony forming units.
choke	Means a full or partial blockage in a sewer pipe that results in sewage being discharged to the environment. A choke may be caused by structural collapse of the sewer pipes, tree roots, debris or siltation.
condition	Means a condition of this licence.
directed overflow	Means a directed overflow structure within the reticulation system.
directed overflow structure	Means a designed structure (excluding access chambers) in the reticulation system which operates as a relief to allow sewage to discharge at a planned location or a sewage pumping station, but does not include a bypass from a sewage treatment plant.
discharges to maintain storage capacity	Discharges which occur during or in anticipation of extreme wet weather events when additional effluent irrigation is not possible and the amount of effluent generated is likely to exceed the effluent storage capacity.
dry weather	Dry weather occurs when less than 10 millimetres of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre
	of the catchment). Dry weather SPS discharge occurs when less than 10mm rainfall has been measured at a rain gauge in the catchment of the SPS during a 24 hour period (where there is no rain gauge in the catchment at the rain gauge closest to the SPS).
dry weather overflow	Means an overflow in the reticulation system not caused by wet weather, as determined by the hydraulic sewer system model.
effluent	Means sewage that has received all of the designed treatment processes at the sewage treatment plant.
emission factor	In relation to load-based licensing, means the level of emissions expected to be generated relative to another characteristic of the activity.
harm	Has the same meaning as in the Protection of the Environment Operations Act 1997.
kL	Means kilolitre.
L/s	Means litres per second.
leakage	Overflows caused by the exfiltration of sewage from faults, such as cracks, in sewer pipes to the surrounding environment.
licence issue date	Means the date of the issue of this licence, or if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.
mL	Means millilitres.

Environment Protection Licence

Licence - 10555

ML	Means megalitres.
node	Is a point in the hydraulic sewer system model that represents one or more overflows in the same catchment.
offensive odour	Has the same meaning as in the Protection of the Environment Operations Act 1997.
overflow	Is a discharge of untreated or partially treated sewage from the sewage treatment system. Overflows may occur as directed overflows or uncontrolled overflows.
Partial disinfection	Means a discharge of sewage or effluent from an STP that occurs when the flow rate of sewage at the influent point of the STP equals or exceeds the rate specified in condition O6.3.
Partial treatment discharge	Means a discharge of sewage or effluent from an STP that occurs when the flow rate of sewage at the influent point of the STP equals or exceeds the rate specified in condition O6.3 for Bondi, Malabar and North Head STPs only.
performance acceptance criteria	In relation to hydraulic sewer stem model, means the standard of accuracy (sometimes called the “goodness of fit”) to be achieved when observations of a particular performance indicator are compared to the results predicted by the model.
precautionary discharge	the controlled release of effluent from the Western Dam into Stonequarry Creek. Releases are related to stream flow and where possible be timed to coincide with high stream flows.
reticulation system	Means that part of the sewage treatment system which collects and transports sewage to the sewage treatment plant and includes all sewer pipes (whether greater or less than 300mm diameter), access chambers, vent shafts, directed overflow structures and sewage pumping stations, but does not include the sewage treatment plant.
SCAMP	Sewer Catchment Asset Management Plan.
sewage	Means all material received in the reticulation system.
sewage products	Means any by-product of the treatment processes and includes biosolids, raw sludge, liquid sludge, thickened sludge, digested sludge, screenings and grit.
sewage pumping station (SPS)	Is a structure which controls the transport of sewage through the sewer pipes, where steep hills and other variations in the land topography can prevent or limit the gravity flow of sewage to the sewage treatment plant.
sewage treatment plant (STP)	Is a facility at which sewage is stored and treated following delivery from the reticulation system prior to discharge, and includes discharge structures and STP bypass points.
sewage treatment system	Means the reticulation system and the sewage treatment plant used for the transport, treatment and discharge of effluent and sewage.
sub-catchment	Sub-catchment boundaries are marked on the system map.
ten year rainfall time series data	Means the rainfall data for the period 1985 to 1994 as used in the EISs.
Trade waste agreements	Means agreements reached between the licensee and industrial and commercial customers to restrict the amount of toxic and other potentially harmful substances discharged to the sewerage system.
ug/L	Means micrograms per litre.
uncontrolled overflow	Means an overflow from any part of the reticulation system that is not a directed overflow. Leakage or overflows from access chambers are examples or uncontrolled overflows.



Environment Protection Licence

Licence - 10555

waters	Has the same meaning as in the Protection of the Environment Operations Act 1997.
waterways	Means the whole or any part of any river, stream, lake, lagoon, swamp, wetlands, natural or artificial watercourse, dam or tidal waters (including the sea), but does not include watercourses that are dry at the commencement of the overflow, or underground pipes, channels or gutters designed to receive or pass rainwater.
wet weather	Wet weather occurs when 10 millimetres or more of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre of the catchment).
wet weather overflow	Means an overflow in the reticulation system caused by wet weather as determined by the hydraulic sewer system model.



Environment Protection Licence

Licence - 10555

Dictionary

General Dictionary

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.
fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 2009.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997

Environment Protection Licence

Licence - 10555

flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
O&G	Means oil and grease
percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .



Environment Protection Licence

Licence - 10555

TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non-putrescible), special waste or hazardous waste
Wellhead	Has the same meaning as in Schedule 1 to the Protection of the Environment Operations (General) Regulation 2021.

Mr Neale Philip

Environment Protection Authority

(By Delegation)

Date of this edition: 30-June-2000

Environment Protection Licence

Licence - 10555

End Notes

- 1 Licence varied by notice 010628, issued on 04-Jul-2000, which came into effect on 29-Jul-2000.
- 2 Licence fee period changed by notice 1011799 on 28-Sep-2001.
- 3 Licence varied by notice 1005279, issued on 22-Oct-2001, which came into effect on 16-Nov-2001.
- 4 Licence varied by notice 1017899, issued on 27-Jun-2002, which came into effect on 28-Jun-2002.
- 5 Licence varied by notice 1018896, issued on 19-Aug-2002, which came into effect on 19-Aug-2002.
- 6 Licence varied by notice 1021142, issued on 23-Dec-2002, which came into effect on 17-Jan-2003.
- 7 Licence varied by notice 1032953, issued on 22-Mar-2004, which came into effect on 02-Apr-2004.
- 8 Licence varied by notice 1047036, issued on 29-Jun-2006, which came into effect on 29-Jun-2006.
- 9 Licence varied by notice 1092453, issued on 05-Nov-2008, which came into effect on 05-Nov-2008.
- 10 Condition A1.3 Not applicable varied by notice issued on <issue date> which came into effect on <effective date>
- 11 Licence varied by notice 1102718, issued on 25-Jun-2009, which came into effect on 25-Jun-2009.
- 12 Licence varied by admin corrections to annual return, issued on 02-Jul-2009, which came into effect on 02-Jul-2009.
- 13 Licence varied by notice 1116042, issued on 02-Jul-2010, which came into effect on 02-Jul-2010.
- 14 Licence varied by notice 1122396, issued on 09-Dec-2010, which came into effect on 09-Dec-2010.
- 15 Licence varied by notice 1128723, issued on 02-Jun-2011, which came into effect on 02-Jun-2011.
- 16 Licence varied by notice 1129098, issued on 23-Jun-2011, which came into effect on 23-Jun-2011.
- 17 Licence varied by notice 1505104 issued on 28-Jun-2012
- 18 Licence varied by notice 1518840 issued on 25-Jun-2014
- 19 Licence varied by notice 1528924 issued on 23-Mar-2015
- 20 Licence varied by notice 1530604 issued on 21-May-2015



Environment Protection Licence

Licence - 10555

21	Licence varied by notice	1538208 issued on 19-Feb-2016
22	Licence varied by notice	1539159 issued on 28-Jun-2016
23	Licence varied by notice	1542296 issued on 27-Jul-2016
24	Licence varied by notice	1544237 issued on 01-Sep-2016
25	Licence varied by notice	1557301 issued on 10-Oct-2017
26	Licence varied by notice	1572511 issued on 30-Nov-2018
27	Licence varied by notice	1577328 issued on 25-Mar-2019
28	Licence varied by notice	1580214 issued on 01-Jul-2019
29	Licence varied by notice	1586316 issued on 04-Oct-2019
30	Licence varied by notice	1587679 issued on 31-Oct-2019
31	Licence varied by notice	1593967 issued on 16-Jun-2020
32	Licence varied by notice	1611954 issued on 27-Aug-2021
33	Licence varied by notice	1615269 issued on 16-Dec-2021
34	Licence varied by notice	1618989 issued on 03-Jun-2022
35	Licence varied by notice	1623850 issued on 27-Oct-2022
36	Licence varied by notice	1626455 issued on 24-May-2023
37	Licence varied by notice	1629834 issued on 26-Jun-2023
38	Licence varied by notice	1630821 issued on 28-Jul-2023