



Environment Protection Licence

Licence - 1725

Licence Details	
Number:	1725
Anniversary Date:	01-July

Licensee	
SYDNEY WATER CORPORATION	
PO BOX 399	
PARRAMATTA NSW 2124	

Premises	
CASTLE HILL SEWAGE TREATMENT SYSTEM INCLUDING THE STP AT	
WRIGHTS ROAD	
KELLYVILLE NSW 2155	

Scheduled Activity	
Sewage treatment	

Fee Based Activity	Scale
Sewage treatment processing by small plants	> 1000-5000 ML annual maximum volume of discharge

Contact Us	
NSW EPA	
6 Parramatta Square	
10 Darcy Street	
PARRAMATTA NSW 2150	
Phone: 131 555	
Email: info@epa.nsw.gov.au	
Locked Bag 5022	
PARRAMATTA NSW 2124	



Environment Protection Licence

Licence - 1725

INFORMATION ABOUT THIS LICENCE	4
Dictionary	4
Responsibilities of licensee	4
Variation of licence conditions	4
Duration of licence	4
Licence review	4
Fees and annual return to be sent to the EPA	4
Transfer of licence	5
Public register and access to monitoring data	5
1 ADMINISTRATIVE CONDITIONS	6
A1 What the licence authorises and regulates	6
A2 Premises or plant to which this licence applies	6
A3 Other activities	7
A4 Information supplied to the EPA	7
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND	7
P1 Location of monitoring/discharge points and areas	7
3 LIMIT CONDITIONS	8
L1 Pollution of waters	8
L2 Load limits	9
L3 Concentration limits	10
L4 Volume and mass limits	12
L5 Waste	12
L6 Noise limits	13
L7 Other limit conditions	13
4 OPERATING CONDITIONS	14
O1 Activities must be carried out in a competent manner	14
O2 Maintenance of plant and equipment	15
O3 Emergency response	15
O4 Processes and management	15
O5 Other operating conditions	17
5 MONITORING AND RECORDING CONDITIONS	17
M1 Monitoring records	17
M2 Requirement to monitor concentration of pollutants discharged	18
M3 Testing methods - concentration limits	20
M4 Testing methods - load limits	20



Environment Protection Licence

Licence - 1725

M5	Environmental monitoring	21
M6	Recording of pollution complaints	21
M7	Telephone complaints line	22
M8	Requirement to monitor volume or mass	22
M9	Requirement to record bypass incidents from sewage treatment plants	23
M10	Other monitoring and recording conditions	23
6	REPORTING CONDITIONS	24
R1	Annual return documents	24
R2	Notification of environmental harm	25
R3	Written report	26
R4	Other notifications	26
R5	Annual system performance report	27
7	GENERAL CONDITIONS	29
G1	Copy of licence kept at the premises or plant	29
G2	Contact number for incidents and responsible employees	30
G3	Signage	30
8	POLLUTION STUDIES AND REDUCTION PROGRAMS	30
U1	Pollution Study 308: Dry weather overflow abatement program 2025-2029	30
U2	Pollution Study 309: Development of choke prioritisation methodologies to produce choke improvement prioritisation lists	31
U3	PRP 308: Choke Improvement Pollution Reduction Program	32
9	SPECIAL CONDITIONS	32
E1	Sydney Water Dry Weather Sewage Overflow Response Report	32
E2	Mandatory Environmental Audit	36
E3	Special Dictionary	42
DICTIONARY		46
	General Dictionary	46

Environment Protection Licence

Licence - 1725

Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act);
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).



Environment Protection Licence

Licence - 1725

The EPA publication “A Guide to Licensing” contains information about how to calculate your licence fees. The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

SYDNEY WATER CORPORATION
PO BOX 399
PARRAMATTA NSW 2124

subject to the conditions which follow.



Environment Protection Licence

Licence - 1725

1 Administrative Conditions

A1 What the licence authorises and regulates

- A1.1 This licence authorises the carrying out of the scheduled development work listed below at the premises listed in A2: Not applicable.
- A1.2 This licence authorises the carrying out of the scheduled activities listed below at the premises specified in A2. The activities are listed according to their scheduled activity classification, fee-based activity classification and the scale of the operation.

Unless otherwise further restricted by a condition of this licence, the scale at which the activity is carried out must not exceed the maximum scale specified in this condition.

Scheduled Activity	Fee Based Activity	Scale
Sewage treatment	Sewage treatment processing by small plants	> 1000 - 5000 ML annual maximum volume of discharge

- A1.3 Not applicable.
- A1.4 The objectives of this licence are to:
- a) require practical measures to be taken to protect the environment and public health from sewage treatment plant effluent and sewer overflows;
 - b) require proper and efficient management of the sewage treatment system to minimise harm to the environment and public health;
 - c) require no deterioration and continuing improvement in the sewage treatment system environmental performance relative to existing conditions; and
 - d) minimise the frequency and volume of overflows and sewage treatment plant bypasses.
- A1.5 This licence is to be construed in a manner that will promote the objectives referred to in A1.4.

A2 Premises or plant to which this licence applies

- A2.1 The licence applies to the following premises:

Premises Details
CASTLE HILL SEWAGE TREATMENT SYSTEM INCLUDING THE STP AT
WRIGHTS ROAD
KELLYVILLE
NSW 2155
LOT 2111 DP 263858, LOT 1 DP 541048, LOT 1 DP 553269, LOT 21 DP 557319

- A2.2 The premises also includes the reticulation system owned and operated by the licensee that is associated with the sewage treatment plant(s) identified in condition A2.1.



Environment Protection Licence

Licence - 1725

A3 Other activities

A3.1 This licence applies to all other activities carried on at the premises, including:

Ancillary Activity
Chemical Storage
Waste Storage

A4 Information supplied to the EPA

A4.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- a) the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- b) the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

A4.2 Notwithstanding condition A4.1, works and activities carried out by the licensee must not be inconsistent with the EPA's Determining Authority Report for the Sewer Overflow Licensing Program, dated May 2000.

2 Discharges to Air and Water and Applications to Land

P1 Location of monitoring/discharge points and areas

- P1.1 Air monitoring points - not applicable.
- P1.2 The following utilisation areas referred to in the table below are identified in this licence for the purposes of the monitoring and/or the setting of limits for any application of solids or liquids to the utilisation area.
- P1.3 The following points referred to in the table are identified in this licence for the purposes of the monitoring and/or the setting of limits for discharges of pollutants to water from the point.

Water and land

EPA Identification no.	Type of Monitoring Point	Type of Discharge Point	Location Description
------------------------	--------------------------	-------------------------	----------------------



Environment Protection Licence

Licence - 1725

1		Discharge to waters	Outfall to Castle Hill Creek approximately 500m downstream of the junction with Cattai Creek labelled "1" on diagram titled "Castle Hill Evacuation Plan" submitted to the EPA 24 June 2005
2		Discharge to utilisation area	Irrigation within fenceline of the STP labelled as "DL002" on map titled "Layout of STP" submitted with Licence Information Form dated 18 June 1999.
3	Volume monitoring and discharge to utilisation area	Volume monitoring and discharge to utilisation area	Pumps from the STP tertiary filters to Castle Hill Country Club labelled "3+8" on diagram titled "Castle Hill STP Evacuation Plant" submitted to the EPA 24 June 2005
4	Volume monitoring		Outlet from disinfection facilities labelled "4+6" on diagram titled "Castle Hill STP Evacuation Plan" submitted to the EPA 24 June 2005
5	Effluent quality monitoring		In the channel between STP tertiary filters and disinfection facilities labelled "5" on drawing titled "Castle Hill STP Evacuation Plan" submitted to the EPA 24 June 2005
6	Effluent quality monitoring		At the outlet from the STP disinfection facilities

P1.4 For the purposes of conditions L2.1, L2.2, L2.7, L2.8 and L2.9, the sewage treatment plant discharges to Sackville 3 sub-zone. Sackville 3 sub-zone is the area labelled ‘Sackville 3’ on the zone map held on EPA electronic file EF15/791.

3 Limit Conditions

L1 Pollution of waters

- L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.
- L1.2 Subject to the conditions of this licence, sewage must not be discharged from the components of the reticulation system except from those components identified on the system map.
- L1.3 Notwithstanding the provisions of the condition above, this licence does not permit the pollution of waters at any time during dry weather from:
- a) uncontrolled overflows, or
 - b) directed overflows other than from sewage pumping stations,
- if a cause of the pollution is failure to:
- i) operate any part of the reticulation system in a proper and efficient manner; or
 - ii) maintain any part of the reticulation system in a proper and efficient condition.
- L1.4 This licence does not permit the pollution of water at any time during dry weather from any pumping station.



Environment Protection Licence

Licence - 1725

This condition is effective from 1 July 2006.

L2 Load limits

L2.1 The actual load of an assessable pollutant discharged from the premises during the reporting period must not exceed the load limit specified for the assessable pollutant in the table below.

Note: An assessable pollutant is a pollutant which affects the licence fee payable for the licence.

L2.2 From 1 July 2024, the load limits for Nitrogen (total) and Phosphorus (total) listed in L2.1 will change to the following values:
a) Nitrogen (total) 82,400 kg/year
b) Phosphorus (total) 1,160 kg/year

L2.3 The actual load of an assessable pollutant must be calculated in accordance with the relevant load calculation protocol.

Assessable Pollutant	Load limit (kg)
BOD (Enclosed Water)	39420.00
Nitrogen (total) (Enclosed Water)	72270.00
Oil and Grease (Enclosed Water)	11498.00
Phosphorus (total) (Enclosed Water)	2300.00
Total suspended solids (Enclosed Water)	42705.00

L2.4 For the purposes of condition L2.1 only, premises means the sewage treatment plant(s) referred to in condition A2.1 of this licence.

L2.5 For the purposes of condition L2.2 and M1.1 the relevant load calculation protocol is the methodology detailed in the document titled “Development of Load Calculation Method and Trial Calculation” (June 2003) approved by the EPA in September 2003 and any subsequent amendments approved by the EPA in writing.

L2.6 Not applicable.

L2.7 From 1 July 2024, the annual load of Nitrogen (total) and Phosphorus (total) discharged from Sydney Water’s sewage treatment plants in the Sackville sub-zone 3 must not result in the aggregated 5 year rolling average load of Nitrogen (total) and Phosphorus (total) exceeding the specified aggregate loads in condition L2.2 in a given year:

- a) Nitrogen (total) 82,400 kg/year
- b) Phosphorus (total) 1,160 kg/year

Note: The loads for the 2024/25 year will be the rolling average of reporting period loads from 2019/20 to 2023/24. Where there have been STP upgrades during this period, the historical loads would be reduced by the load reductions achieved by the upgrades, to obtain an equivalent historical load for use in the rolling average calculations.



Environment Protection Licence

Licence - 1725

- L2.8 From 1 July 2024, the annual load targets from Sydney Water’s sewage treatment plants discharging to Sackville sub-zone 3 are the following aggregated 5 year rolling average loads of Nitrogen (total) and Phosphorus (total):
- a) Nitrogen (total) 74,900 kg/year
 - b) Phosphorus (total) 1,050 kg/year

Note: The loads for the 2024/25 year will be the rolling average of reporting period loads from 2019/20 to 2023/24. Where there have been STP upgrades during this period, the historical loads would be reduced by the load reductions achieved by the upgrades, to obtain an equivalent historical load for use in the rolling average calculations.

- L2.9 The licensee may use nutrient load offset trading to reduce or increase the aggregated 5 year rolling average load of Nitrogen (total) and Phosphorus (total) in L2.7 and L2.8 in accordance with the protocol detailed in the document titled “*Compliance offsets for nutrient discharges to the Hawkesbury-Nepean River - Interim Operational Protocol 2018 to 2024 (July 2019)*” by BDA Group held on EPA electronic file EF15/791.

L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table/s below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 Where a pH quality limit is specified in the table, the specified percentage of samples must be within the specified ranges.
- L3.3 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table/s.
- L3.4 Water and/or Land Concentration Limits

POINT 1

Pollutant	Units of Measure	Average concentration limit	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Aluminium	micrograms per litre	160	-	400	-
Cadmium	micrograms per litre	0.2	-	0.2	-
Copper	micrograms per litre	8	-	11	-



Environment Protection Licence

Licence - 1725

Diazinon	micrograms per litre	0.2	-	0.1	-
Hydrogen sulfide (un-ionised)	micrograms per litre	30	-	60	-
Iron	micrograms per litre	360	-	1100	-
Nitrogen (ammonia)	milligrams per litre	-	0.9	1.4	-
Nitrogen (total)	milligrams per litre	-	20	25	-
Phosphorus (total)	milligrams per litre	-	0.3	1	-
Zinc	micrograms per litre	29	-	37	-

POINT 2,3

Pollutant	Units of Measure	Average concentration limit	50 percentile concentration limit	90 percentile concentration limit	100 percentile concentration limit
Nitrogen (ammonia)	milligrams per litre	-	1	5	-
Nitrogen (total)	milligrams per litre	-	20	25	-
Phosphorus (total)	milligrams per litre	-	0.3	1	-

POINT 1, 2 and 3

Pollutant	Units of Measure	3DGM concentration limit	50 percentile concentration limit	90 percentile concentration limit
Biochemical oxygen demand	milligrams per litre	30	7	10
Total suspended solids	milligrams per litre	10	5	10
Faecal coliforms	colony forming units per 100 millilitres	-	-	200*

Note: The faecal coliforms concentration limit marked by an asterisk in the above table is to be interpreted as an 80% concentration limit for the purpose of assessing compliance with this condition.

L3.5 From 1 July 2024, the concentration limits for Nitrogen (total) and Phosphorus (total) listed in L3.4 for Points 1 and 2 will change to the following values:



Environment Protection Licence

Licence - 1725

- a) Nitrogen (total) 6 mg/L (50 percentile concentration limit)
- b) Phosphorus (total) 0.1 mg/L (50 percentile concentration limit)

Note: The 100 percentile limits for Nitrogen (total) and Phosphorus(total) will cease to apply from 1 July 2024.

- L3.6 When a wet weather bypass flow is occurring, exceedances of the 3DGM concentration limits in condition L3.4 are permitted at the following point(s) for the duration of the bypass where the bypass was the sole cause of the exceedance: Points 1,2 and 3.
- L3.7 Not applicable.
- L3.8 For each monitoring/discharge point specified in the table(s) below (by a point number), the specified toxic effect of the effluent on the specified test organism must be greater than the corresponding limit listed for that organism in the table.

POINT 1

Toxicity	Units of Measure	50 percentile limit
Ceriodaphnia dubia immobilization (EC50)	percent effluent by volume	50

L4 Volume and mass limits

- L4.1 For each discharge point or utilisation area specified below (by a point number), the volume/mass of:
- a) liquids discharged to water; or;
 - b) solids or liquids applied to the area;
- must not exceed the volume/mass limit specified for that discharge point or area.

Point	Unit of Measure	Volume/Mass Limit
1	kilolitres per day	80000
2	kilolitres per day	80000
3	kilolitres per day	80000

- L4.2 Notwithstanding the volume limits specified in condition L4.1, the combined volume discharged from point(s) 1, 2 and 3 must not exceed 80,000 kL/day.

L5 Waste

- L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.

Environment Protection Licence

Licence - 1725

- L5.2 This condition only applies to the storage, treatment, processing, reprocessing or disposal of waste at the premises if those activities require an environment protection licence.
- L5.3 The licensee may receive and/or transfer sewage generated outside the premises for treatment, processing or reprocessing at the premises. The licensee must take reasonable steps to ensure that sewage received at the premises has been lawfully discharged in accordance with a trade waste agreement or customer contract (as applicable) in force between the licensee and the generator of the waste. The licensee must treat, process or reprocess the sewage in accordance with this licence prior to discharge from the premises.
- L5.4 The licensee may receive, store, treat, process or reprocess and/or transfer at the premises sewage products generated or stored outside the premises by the licensee's other sewage treatment systems. Sewage products must be received, treated, processed or reprocessed in accordance with this licence.

L6 Noise limits

- L6.1 Not applicable.

L7 Other limit conditions

L7.1 Hydraulic Sewer System Model

- a) The licensee must maintain a hydraulic sewer system model which has no temporal or magnitude bias in either flow volume or water levels at the licence gauges as referenced in the document titled "PRP101.1 System Model Performance Indicators, September 2000" and subsequent modifications made by the Criteria Review Committee.
- b) The licensee must undertake an annual Quality System audit of the hydraulic sewer system model to determine if the model used during that reporting period meets the standards set out in condition L7.1(a).
- c) The licensee must prepare a written report on each Quality System audit of any model used to assess sewage system wet weather overflow performance for the purpose of determining compliance with this licence. The report must also include the Pearson's correlation coefficient for the model used during the reporting period.
- d) The licensee must provide a written report with each Annual Return on any Quality System audit of the hydraulic sewer system model stating the methodology and results of the audit.
- e) The licensee must convene an Independent Criteria Review Committee at least once every three Reporting Periods to review the methodology and findings of each of the Quality System audits.
- f) The licensee must ensure that the Independent Criteria Review Committee prepares a written report on the review required by condition L7.1(e).
- g) The licensee must submit to the EPA a copy of each Independent Criteria Review Committee report received by the licensee in a particular Reporting Period with the following Annual Sewage Treatment System Performance Report required by condition R5 of this licence.

L7.2 Wet weather overflow limits

The frequency of wet weather overflows from the reticulation system must not exceed 20 overflows per 10

Environment Protection Licence

Licence - 1725

years. Compliance with this condition must be determined at the end of each reporting period against the frequency predicted using the hydraulic sewer system model required by condition L7.1 with the 10 year rainfall time series data.

L7.3 The licensee must report the number of wet weather overflows per 10 years as determined using the hydraulic sewer system model required by condition L7.1.

L7.4 Dry weather overflow limits

Not applicable.

L7.5 Choke improvement requirements

Note: The objective of this condition is to require continuous reductions in impacts to the environment and community from chokes by requiring the licensee to achieve set improvement levels within defined periods based on abatement works in prioritised areas.

a) By 31 December 2024 and then again by 31 December 2027, and thereafter at intervals of not greater than every five years, the licensee must submit to the EPA a proposed choke improvement prioritisation list. The list must be based on the scope of all the areas in Sydney Water's licensed reticulation systems.

b) For the purposes of producing the choke improvement prioritisation list as required by condition L7.5a), the licensee must determine the prioritisation of choke improvement areas using the applicable methodologies developed in accordance with the relevant conditions of Pollution Study 309.

Note: Upon acceptance by the EPA, the choke improvement prioritisation list will form the basis for an associated improvement level imposed under PRP 308, and the licensee will have a maximum of five years to achieve that improvement level.

c) The licensee must achieve the improvement levels in PRP 308 by the associated completion date specified.

d) Within three months after a completion date specified in PRP 308, the licensee must provide a report to the EPA demonstrating compliance or otherwise with condition L7.5c).

4 Operating Conditions

O1 Activities must be carried out in a competent manner

O1.1 Licensed activities must be carried out in a competent manner.

This includes:

- a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
- b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

O1.2 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed in



Environment Protection Licence

Licence - 1725

accordance with the Biosolids Guidelines, or as otherwise approved in writing by the EPA.

O2 Maintenance of plant and equipment

- O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
- a) must be maintained in a proper and efficient condition; and
 - b) must be operated in a proper and efficient manner.

O3 Emergency response

- O3.1 In the event of an overflow from the reticulation system or a bypass from a sewage treatment plant that harms or is likely to harm the environment or present a significant public health risk, the licensee must take all reasonable and feasible actions as soon as practicable to minimise the impact of the overflow or bypass on the environment and public health.

For the avoidance of doubt, the requirements of this condition are in addition to any measures required to be implemented in accordance with the Pollution Incident Response Management Plan required to be prepared and implemented under Part 5.7A of the Protection of the Environment Operations Act 1997.

O4 Processes and management

O4.1 Appropriate Treatment Processes

Sewage or effluent must not be discharged from points 1 and 2 unless it has been treated in accordance with the requirements of the table below.

The flows specified in the table below are the effluent from the sewage treatment plant.

Required treatment process	Flow range
Screening, degritting, primary and secondary sedimentation, activated sludge treatment, tertiary filtration and disinfection	Less than 230L/s
Screening and disinfection	230L/s or more
Partial disinfection	300L/s or more

- O4.2 During any tertiary filter overhaul works when two tertiary filters are online and one tertiary filter is offline for maintenance, the required treatment process flow range specified in O4.1 is superseded by the flow range specified in the table below.

The flows specified in the table below are the effluent from the sewage treatment plant.

Required treatment process	Flow range
----------------------------	------------



Environment Protection Licence

Licence - 1725

Screening, degritting, primary and secondary sedimentation, activated sludge treatment, tertiary filtration, and disinfection	Less than 160L/s
Screening, degritting, primary and secondary sedimentation, activated sludge treatment and disinfection	Less than 230L/s
Screening and disinfection	230L/s or more
Partial disinfection	300L/s or more

O4.3 During any tertiary filter overhaul works when one tertiary filter is online, the second tertiary filter is in a backwashing cycle and the third tertiary filter is offline for maintenance, the required treatment process flow range specified in O4.1 is superseded by the flow range specified.

The flows specified in the table below are the effluent from the sewage treatment plant.

Required treatment process	Flow range
Screening, degritting, primary and secondary sedimentation, activated sludge treatment, tertiary filtration, and disinfection	Less than 80L/s
Screening, degritting, primary and secondary sedimentation, activated sludge treatment and disinfection	Less than 230L/s
Screening and disinfection	230L/s or more
Partial disinfection	300L/s or more

O4.4 The Licensee may undertake major periodic maintenance on the tertiary filters in accordance with licence conditions O4.2 and O4.3, if approved in writing by an EPA Officer.

O4.5 Not applicable.

O4.6 Not applicable.

O4.7 **Level of reticulation system management, operations and maintenance activities**

The reticulation system must be managed, operated and maintained such that the operational and maintenance works and activities result in ongoing improvement in the system environmental performance, when compared with existing system environmental performance. The system environmental performance must not at any time fall below existing system environmental performance.

O4.8 For the purposes of determining whether the system environmental performance has fallen below existing system environmental performance:

a) in relation to chokes, the licensee is to compare the average number of chokes per year per 100km of pipe in the reticulation system of all of the licensee’s sewage treatment systems averaged over the period 1 July 1995 to 30 June 2000 to the average annual number of chokes averaged over all of the licensee’s sewage treatment systems over the reporting period and the preceding four twelve month periods;

Environment Protection Licence

Licence - 1725

- b) in relation to odour complaints, the licensee is to compare the number of odour complaints from the reticulation system per year averaged over the period 1 July 1995 to 30 June 2000 to the average annual number of odour complaints over the reporting period and the preceding four twelve month periods;

O4.9 Exceedance of design capacity of primary disinfection processes

- a) The sewage treatment system must be operated and maintained such that the operational and maintenance works and activities must not at any time increase the frequency at which the effluent flow rate exceeds the design capacity of the primary disinfection process.
- b) For the purposes of determining compliance with (a), the licensee must compare the number of times the design capacity of the primary disinfection process is exceeded per 10 years as predicted by the hydraulic sewer system model for 1994 to the number of times the design capacity of the primary disinfection process is exceeded per 10 years as predicted by the hydraulic sewer system model for the reporting period. This comparison must use the 10 year rainfall time series data in each model.
- c) An exceedance of the design capacity of the primary disinfection process occurs when the effluent flow rate of sewage from the sewage treatment plant equals or exceeds 300L/s.
- d) When the primary disinfection process is bypassed or otherwise fails, total residual chlorine discharges are permitted at points 1 and 2 until the primary disinfection process is restored.
- e) The licensee must take all actions necessary to restore the operation of the primary disinfection process as soon as the licensee or one of the licensee's employees or agents becomes aware that the primary disinfection process is being bypassed or has failed.

O5 Other operating conditions

O5.1 Prohibition on acceptance of pesticides

The licensee must not consent to any discharge of organophosphate pesticides (including chlorpyrifos, diazinon, malathion) or organochlorine pesticides (including dieldrin, heptachlor and chlordane) into the sewage treatment system.

5 Monitoring and Recording Conditions

M1 Monitoring records

- M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.
- M1.2 All records required to be kept by this licence must be:
- in a legible form, or in a form that can readily be reduced to a legible form;
 - kept for at least 4 years after the monitoring or event to which they relate took place; and
 - produced in a legible form to any authorised officer of the EPA who asks to see them.
- M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:



Environment Protection Licence

Licence - 1725

- a) the date(s) on which the sample was taken;
- b) the time(s) at which the sample was collected;
- c) the point at which the sample was taken; and
- d) the name of the person who collected the sample.

M1.4 Registers

The licensee must maintain and make available for inspection by the public, at the licensee's Head Office, registers recording the following information, for the sewage treatment system:

- a) a map or maps of the sewage treatment system showing:
 - i) the location of the sewage treatment plant or plants, sewage pumping stations, directed overflow structures, pipes and access chambers in the sewage treatment system, referenced by the licensee's identifier and the EPA point identification number, as applicable;
 - ii) the catchments, sub-catchments and sensitive areas relevant to the sewage treatment system;
- b) the number of chokes within the system reported to the licensee during each reporting period;
- c) a schedule of proposed works to be carried out in relation to the premises during each reporting period;
- d) the works completed in relation to the premises during each reporting period; and
- e) the complaints by type recorded under M7 during each reporting period.

M1.5 Changes to the system map must be recorded by reference to the date of the change, description of the change and the name of the person authorising the change.

M2 Requirement to monitor concentration of pollutants discharged

M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified in Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

M2.2 Not applicable.

M2.3 Water and/ or Land Monitoring Requirements

POINT 5

Pollutant	Units of measure	Frequency	Sampling Method
Aluminium	micrograms per litre	12 Times a year	Composite sample
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	Composite sample
Cadmium	micrograms per litre	12 Times a year	Composite sample
Cobalt	micrograms per litre	2 Times a year	Composite sample
Copper	micrograms per litre	12 Times a year	Composite sample
Diazinon	micrograms per litre	12 Times a year	Composite sample
Iron	micrograms per litre	12 Times a year	Composite sample



Environment Protection Licence

Licence - 1725

Nitrogen (ammonia)	milligrams per litre	Every 6 days	Composite sample
Nitrogen (total)	milligrams per litre	Every 6 days	Composite sample
Phosphorus (total)	milligrams per litre	Every 6 days	Composite sample
Total suspended solids	milligrams per litre	Special Frequency 1	Composite sample
Zinc	micrograms per litre	12 Times a year	Composite sample

POINT 6

Pollutant	Units of measure	Frequency	Sampling Method
Faecal Coliforms	colony forming units per 100 millilitres	Every 6 days	Grab sample
Hydrogen sulfide (un-ionised)	micrograms per litre	12 Times a year	Grab sample
Toxicity	percent effluent by volume	12 Times a year	Grab sample

M2.4 For the purposes of the tables above Special Frequency 1 means:
For the purposes of determining compliance with the average and percentile limits sampling must be undertaken every 6 days. For the purposes of determining compliance with the "3DGM limits" sampling must be undertaken every month over three consecutive days commencing on the day a sample is taken to determine compliance with the average and percentile limits.

- M2.5 The following conditions apply to the monitoring requirements under condition M2:
- a) where a monitoring frequency is specified as 2 times a year, monitoring must be undertaken at a minimum of 160 day intervals;
 - b) where a monitoring frequency is specified as 4 times a year, monitoring must be undertaken at a minimum of 80 day intervals;
 - c) where a monitoring frequency is specified as 6 times a year, monitoring must be undertaken at a minimum of 50 day intervals; and
 - d) where a monitoring frequency is specified as 12 times a year, monitoring must be undertaken at a minimum of 25 day intervals.

M2.6 The monitoring results collected in accordance with conditions M2 for points 5 and 6 can be used to determine compliance with the limits in conditions L3.4 for points 1, 2 and 3.

M2.7 Subject to M2.8, where the licensee is unable to carry out any sampling required under condition M2 at the required frequency or interval or both because of a circumstance set out in column 1 of the Table below, the licensee is taken to have carried out the sampling at the required frequency or interval or both, as the case may be, if the licensee collects the required sample within the corresponding timeframe in column 2 of the Table.

No.	Column 1	Column 2
-----	----------	----------



Environment Protection Licence

Licence - 1725

1	The unforeseen loss of power supply to the essential monitoring equipment that cannot be rectified by the reasonable provision and operation of standby generators	Within 48 hours of power being restored to the premises
2	The inability of the licensee to access or safely access the monitoring site or equipment due to tidal or fluvial flooding	As soon as practicable once flooding has ceased or abated
3	The failure or malfunction of essential monitoring equipment caused by tidal or fluvial flooding	Within 48 hours after failure or malfunction of essential monitoring equipment has ceased

- M2.8 The licensee must collect and analyse the required number of samples for the reporting period as specified in conditions M2.3 – M2.5 above.
- M2.9 The licensee must keep records of all circumstances listed in column 1 of the Table in condition M2.7 which triggered sample collection in accordance with column 2 of the same Table, including information that can demonstrate that the circumstances in column 1 applied and that the sampling was carried out in accordance with the timeframe prescribed in column 2 of that Table. The licensee must keep these records for a period of 5 years after the end of the reporting period in which the circumstances occurred.
- M2.10 The record must be produced to any authorised officer of the EPA who requests to see them.

M3 Testing methods - concentration limits

- M3.1 Not applicable.
- M3.2 Subject to any express provision to the contrary in this licence, monitoring for the concentration of a pollutant discharged to waters or applied to a utilisation area must be done in accordance with the Approved Methods Publication unless another method has been approved by the EPA in writing before any tests are conducted.
- M3.3 The requirements of condition M3.2 also apply to the monitoring of the concentration of pollutants in waters.
- M3.4 Monitoring for effluent toxicity must be conducted in accordance with the relevant testing methods listed below:

Bailey, H.C., Krasso, R., Elphick, J.R., Mulhall, A-M., Hunt, P., Tedmanson, L. & Lovell, A. (2000), 'Application of Ceriodaphnia dubia for whole effluent toxicity tests in the Hawkesbury-Nepean watershed, New South Wales, Australia: Method development and validation', Environmental Toxicology and Chemistry: Vol. 19, No. 1, pp. 88–93.

Any proposed deviation from the methods listed above must be approved in writing by the EPA prior to the use of any other method.

M4 Testing methods - load limits

Note: Division 4 of the *Protection of the Environment Operations (General) Regulation 2022* requires that monitoring of actual loads of assessable pollutants listed in L2.2 must be carried out in accordance with the

Environment Protection Licence

Licence - 1725

relevant load calculation protocol set out for the fee-based activity classification listed in the Administrative Conditions of this licence.

M5 Environmental monitoring

M5.1 Sydney Water Aquatic Monitoring (SWAM) Program

a) From 1 July 2023 onward, the licensee must undertake the monitoring programs detailed in the Sydney Water publication "Sydney Water Aquatic Monitoring (SWAM) Program, Version 1, April 2023", or in any replacement document approved in writing by the EPA.

b) The licensee must maintain a database of the results obtained in undertaking monitoring programs specified in the document cited above, as well as monitoring programs previously undertaken under the publication "Sewage Treatment System Impact Monitoring Program, December 2010" (the STSIMP Document). Information from the database must be made available to any authorised officer of the EPA on request.

c) The licensee must provide to the EPA the reports specified in the document cited above.

d) The "SWAM Annual Data Report: All regions" specified in the document cited above must be submitted not later than 15 December in each year.

e) The "SWAM Interpretative Report – Inland, estuarine, lagoon and nearshore marine waters" and "SWAM Interpretative Report – Offshore marine waters" (the SWAM Interpretative Reports) specified in the document cited above must be submitted in the first year of each new pricing cycle for the licensee as determined by the NSW Independent Pricing and Regulatory Tribunal (IPART).

f) For the purposes of condition e) above, the next SWAM Interpretative Reports must be submitted by 31 December 2025.

g) The licensee must continue to undertake the monitoring programs and reporting specified in the STSIMP Document until the commencement of the SWAM Program. This includes:

- i) the continuation of monitoring programs in the STSIMP Document until 30 June 2023
- ii) the provision of the "Sewage Treatment System Impact Monitoring Program (STSIMP): Annual Data Report" to the EPA by no later than 15 December 2023.

Note: Copies of reports relating to the SWAM Program can be found at:

<https://www.sydneywater.com.au/water-the-environment/how-we-manage-sydneys-water/wastewater-network/wastewater-monitoring.html>

M6 Recording of pollution complaints

M6.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.

M6.2 The record must include details of the following:



Environment Protection Licence

Licence - 1725

- a) the date and time of the complaint;
- b) the method by which the complaint was made;
- c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
- d) the nature of the complaint;
- e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
- f) if no action was taken by the licensee, the reasons why no action was taken.

M6.3 The record of a complaint must be kept for at least 4 years after the complaint was made.

M6.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M7 Telephone complaints line

- M7.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.
- M7.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.
- M7.3 The preceding two conditions do not apply until 3 months after: the date of the issue of this licence.

M8 Requirement to monitor volume or mass

- M8.1 For each discharge point or utilisation area specified below, the licensee must monitor:
- a) the volume of liquids discharged to water or applied to the area;
 - b) the mass of solids applied to the area;
 - c) the mass of pollutants emitted to the air;
- at the frequency and using the method and units of measure, specified below.

POINT 3

Frequency	Unit of Measure	Sampling Method
Continuous during discharge	kilolitres per day	Method approved in writing by the Authority

POINT 4

Frequency	Unit of Measure	Sampling Method
Continuous	kilolitres per day	Level sensor and continuous logger

M8.2 The monitoring results collected in accordance with condition M8.1 for point(s) 3 and 4 can be used to determine compliance with the limits in condition L4.1 for point(s) 1 and 2.

M8.3 In the event that the licensee cannot comply with a volume monitoring method as required by this licence solely due to the failure or malfunction of essential monitoring equipment, volume may be calculated using

Environment Protection Licence

Licence - 1725

another agreed method approved in writing by the EPA. This provision only applies for the duration of the failure or malfunction and the licensee is to rectify the failure or malfunction as soon as practical.

M9 Requirement to record bypass incidents from sewage treatment plants

M9.1 The licensee must record the following details in relation to each bypass from the premises:

- a) the EPA point identification number through which the bypass discharged;
- b) the start time, date and duration of the bypass;
- c) the estimated volume of the bypass;
- d) the level of treatment at the sewage treatment plant prior to discharge;
- e) classification as a dry or wet weather bypass;
- f) the most likely cause of the bypass; and
- g) the name or names of the treatment process or processes bypassed.

M9.2 A dry weather bypass is a bypass that occurs when the effluent flow rate of sewage from the sewage treatment plant does not exceed 150L/s and a wet weather bypass occurs when this flow is equalled or exceeded.

M10 Other monitoring and recording conditions

M10.1 Continuation of Monitoring Programs

The licensee must conduct the following monitoring:

- a) continuation of all sewage treatment system and environmental monitoring programs related to sewer overflows that are underway as of 30 June 1999; and
- b) that monitoring identified at 2.2.4 in the Sydney Water document "Licensing Sewerage Overflows: Methods" dated June 1998 (a copy of which may be inspected at the EPA's Library), unless varied with the prior written approval of the EPA.

M10.2 Biosolids

Biosolids at the premises must be recorded, monitored and classified in accordance with the Biosolids Guidelines, or as otherwise approved in writing by the EPA.

M10.3 Dry weather leakage monitoring program

- a) The licensee must monitor (using results obtained by sampling and analysis) the concentration of faecal coliforms in samples collected from each sampling point identified on the spreadsheet titled "Dry Weather Leakage Monitoring Program SCAMP sampling locations master spreadsheet" and associated maps submitted to the EPA (EPA Reference: SF19/48619).
- b) The licensee must undertake the dry weather leakage monitoring at an annual frequency at each SCAMP monitoring point referenced in M10.3 a), unless subject to clause M10.6, using sampling method grab sample, units of measure of cfu/100mL.
- c) The licensee must seek approval in writing from the EPA to make changes to the dry weather leakage monitoring program SCAMP sampling locations.
- d) Within two weeks of receiving approval from the EPA, the licensee must update the master spreadsheet and associated maps referenced in condition M10.3a and provide the EPA with a copy of the updated

Environment Protection Licence

Licence - 1725

documents.

M10.4 Investigations and remedial action for dry weather leakage

- a) The licensee must investigate the cause of faecal coliform presence in samples collected as per M10.3 a) and M10.3 b) where the analysis results indicate an exceedance in the threshold of 10,000 cfu/100mL ("the threshold"). Investigations will be assigned a priority based on potential risk to the environment and public health and commence accordingly.
- b) The licensee must take remedial action where any investigation undertaken identifies the reticulation system as the cause of the exceedance of the threshold for faecal coliform specified in condition M10.4(a).
- c) The licensee must record:
 - i) the method, results and conclusions of investigations undertaken in accordance with condition M10.4(a), and
 - ii) actions taken by the licensee as a result of the conclusions of the investigations.

M10.5 When analysis results of three consecutive annual routine monitoring samples collected at a SCAMP monitoring point referenced in M10.3 a) exceeds the threshold for faecal coliforms specified in condition M10.4 a), the licensee must, in addition to the actions set out in condition M10.4, notify the EPA in writing as soon as practicable, providing the three sample analysis results, identifying the relevant SCAMP and providing the outcomes of any relevant investigations and remediation actions undertaken.

M10.6 When analysis results of three consecutive annual routine monitoring samples collected at a SCAMP monitoring point referenced in M10.3 a) exceeds the threshold for faecal coliforms specified in condition M10.4 a), the licensee must commence sampling at the relevant sampling location referenced in M10.3 a) on a quarterly basis, unless otherwise approved in writing by the EPA. Sampling must be undertaken at quarterly intervals until three consecutive routine samples are below the threshold, at which time the frequency of sampling at the location can revert to an annual frequency as specified in M10.3 b).

6 Reporting Conditions

R1 Annual return documents

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:

1. a Statement of Compliance,
2. a Monitoring and Complaints Summary,
3. a Statement of Compliance - Licence Conditions,
4. a Statement of Compliance - Load based Fee,
5. a Statement of Compliance - Requirement to Prepare Pollution Incident Response Management Plan,
6. a Statement of Compliance - Requirement to Publish Pollution Monitoring Data; and
7. a Statement of Compliance - Environmental Management Systems and Practices.

At the end of each reporting period, the EPA will provide to the licensee notification that the Annual Return is



Environment Protection Licence

Licence - 1725

due.

R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

R1.3 Where this licence is transferred from the licensee to a new licensee:

- a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
- b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:

- a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
- b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

R1.5 The Annual Return for the reporting period must be supplied to the EPA via eConnect *EPA* or by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

R1.6 Where the licensee is unable to complete a part of the Annual Return by the due date because the licensee was unable to calculate the actual load of a pollutant due to circumstances beyond the licensee's control, the licensee must notify the EPA in writing as soon as practicable, and in any event not later than the due date. The notification must specify:

- a) the assessable pollutants for which the actual load could not be calculated; and
- b) the relevant circumstances that were beyond the control of the licensee.

R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.

R1.8 Within the Annual Return, the Statements of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:

- a) the licence holder; or
- b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

R2 Notification of environmental harm

Note: The licensee or its employees must notify all relevant authorities of incidents causing or threatening material harm to the environment immediately after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

Environment Protection Licence

Licence - 1725

- R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which they became aware of the incident.

R3 Written report

- R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
- a) where this licence applies to premises, an event has occurred at the premises; or
 - b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence,
- and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.
- R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.
- R3.3 The request may require a report which includes any or all of the following information:
- a) the cause, time and duration of the event;
 - b) the type, volume and concentration of every pollutant discharged as a result of the event;
 - c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
 - d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
 - e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
 - f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
 - g) any other relevant matters.
- R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

R4 Other notifications

- R4.1
- a) Notwithstanding notification requirements under condition R2, the licensee must notify the EPA of incidents where:
 - i. a dry weather sewage overflow from a sewage pumping station or
 - ii. sewage or effluent not treated at the sewage treatment plant in accordance with the requirements of conditions O4.1 – O4.6 has been discharged to, or is reasonably expected to discharge to, waterways.
 - b) Notifications must be made to the EPA by contacting the Environment Line as soon as practicable after the licensee becomes aware of the incident.
 - c) The notification should include the relevant information as per s150 of the Protection of Environment Operations Act.
 - d) Where an incident has been reported under condition R2 there is no requirement to report it under condition R4 in addition to the report made under condition R2.

Environment Protection Licence

Licence - 1725

Note: Notifications must be made to the other agencies such as Beachwatch, National Parks and NSW Food Authority, where relevant. The requirements for such notifications must be included in Pollution Incident Response Management Plans.

Note: The reporting requirements in condition R4 do not replace any other reporting requirements in the licence or under the Protection of the Environment Operations Act 1997.

R5 Annual system performance report

R5.1 The licensee must supply to the EPA an Annual Sewage Treatment System Performance report not later than 30 September following the end of each reporting period.

R5.2 The Annual Sewage Treatment System Performance Report is to supplement the Annual Return and must report but not be limited to the following components:

R5.3 Effluent discharged

- a) The percentile values calculated from the monitoring data for each pollutant which has corresponding limits.
- b) The annual load of all assessable pollutants.
- c) An analysis of the sewage treatment plant performance against the concentration, toxicity and load limits specified in the licence.
- d) An assessment of the current year's sewage treatment plant performance against the previous five year's performance. The assessment must include but not be limited to an explanation of any observed trends in the sewage treatment plant performance, and the reason for such trends.
- e) The load of Phosphorous (total) and Nitrogen (total) discharged from the sewage treatment plant expressed as a percentage of the total load of Phosphorous (total) and Nitrogen (total) directly discharged from all Sydney Water sewage treatment systems to the Hawkesbury-Nepean.
- f) The total volume discharged from the sewage treatment plant, and the average volume discharged from the sewage treatment plant during dry weather.
- g) The total volume and percentage volume of effluent recycled.
- h) i) The total number of sewage treatment plant bypasses and the total volume discharged that did not receive required treatment during:
 - AA) dry weather; and
 - BB) wet weather
 ii) A summary report of all bypass events which includes, but is not limited to, the following: classification as a dry or wet weather bypass, duration, volume discharged, volume treated, receiving waters, cause, treatment process(es) bypassed and any action(s) taken

R5.4 Biosolids

Reporting requirements in accordance with the Biosolids Guidelines

R5.5 Reticulation System

- a) Dry weather leakages:
 - i) monitoring results from each SCAMP;



Environment Protection Licence

Licence - 1725

- ii) outcomes of any investigations; and
- iii) details of rectification action taken.
- b) Dry weather overflows from chokes and sewage pumping stations:
 - i) including;
 - AA) number of dry weather overflows to waterways, for the whole system and for each SCAMP;
 - BB) total number of dry weather overflows, for the whole system and for each SCAMP;
 - CC) total number of dry weather overflows per 100km for whole system;
 - DD) the name of each sewage treatment system which exceeded the dry weather overflow limit at condition L7.4; and
 - EE) the name of each SCAMP where the number of dry weather overflows reaching waterways in a SCAMP exceeds the target for that SCAMP specified in the SCAMP table below.
 - ii) comparison of the dry weather overflow performance against the previous four twelve month periods for dry weather overflows to waterways and total dry weather overflows.
- c) Where the dry weather overflow sewage treatment system limit at condition L7.4 and/or target in the SCAMP table below was exceeded during the reporting period, the licensee must provide a report to the EPA no later than 30 September each year explaining the reason for the exceedance, which should include but not be limited to:
 - i) an analysis of the exceedances of limit(s) and / or target(s), including the determination of any long-term trends and evaluation of dry weather overflow abatement programs implemented by the licensee;
 - ii) the details of any dry weather overflow abatement investigations, works and activities that were scheduled to be undertaken during the reporting period and which were completed;
 - iii) the details of any dry weather overflow abatement investigations, works and activities that were scheduled to be undertaken during the reporting period and which were not undertaken or not completed;
 - iv) the details of any dry weather overflow abatement investigations, works and activities the licensee will undertake in subsequent reporting periods to minimise the likelihood of the limit(s) and / or target(s) being exceeded in any future reporting period, including the timeframes for those actions to be implemented and the level of prioritisation given to each sewage treatment system and / or SCAMP; and
 - v) an assessment of whether any amendment to the dry weather overflow abatement investigations, works and activities scheduled for the remaining reporting periods to 30 June 2015 is required to achieve the dry weather overflow limits and / or targets at condition L7.4 and in the SCAMP table below.

SCAMP table

SCAMP Name	Dry weather overflows reaching waterways per annum
S_CASTLE_HILL_STS	4

R5.6 Wet weather overflow abatement

- a) Wet weather overflow performance relative to the long term wet weather overflow limit required by conditions L7.2 or the interim wet weather overflow target required by conditions at PRP302, including whether the wet weather overflow limit or interim wet weather overflow target was acheived.

Environment Protection Licence

Licence - 1725

- b) Where the wet weather overflow limit or the interim wet weather overflow target was not achieved, the licensee must provide a statement explaining the reason for the non-compliance, which includes:
- i) the details of any investigations, works and activities that were scheduled to be undertaken during the reporting period and which were completed;
 - ii) the details of any investigations, works and activities that were scheduled to be undertaken during the reporting period and which were not undertaken or not completed;
 - iii) an assessment of whether any amendment to the investigations, works and activities scheduled for the remaining reporting periods to 30 June 2015 is required to achieve the requirements of conditions L7.2 or PRP302.

R5.7 Complaints and reports

A breakdown of the total number of complaints and reports received by the licensee in relation to the premises into categories of “odours”, “water pollution – sewage treatment plant”, “water pollution – reticulation system”, and any other category indicated by the complaint/report. A brief description of any significant unresolved issues arising out of the complaints and reports must be provided.

R5.8 The Annual Sewage Treatment System Performance Report must be presented in a format approved in writing by the EPA.

R5.9 Target nutrient loads (applicable from 1 July 2024)

- a) The licensee must report the Nitrogen (total) and Phosphorus (total) from Sydney Water’s sewage treatment plants discharging to Sackville sub-zone 3 relative to the annual load targets in condition L2.8 including whether the targets were achieved. The report is to include a summary of any investigations, programs, projects, works or activities, including offsets, that were completed that contributed to the achieving of the targets.
- b) Where the annual load targets were not achieved, the licensee must provide a statement explaining the reasons for exceeding the targets which includes:
- i. a summary of any investigations, programs, projects, works or activities, including offsets, that were completed with the intent of achieving the targets
 - ii. a summary of any planned investigations, programs, projects, works or activities, including offsets that were not undertaken or completed
 - iii. a summary of what will be done in the next reporting period to achieve the targets including an assessment of whether an amendment to the investigations, programs, projects, works or activities, including offsets is required to achieve the targets in conditions L2.8.

7 General Conditions

G1 Copy of licence kept at the premises or plant

G1.1 A copy of this licence must be kept at the premises to which the licence applies.

G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.

G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the

Environment Protection Licence

Licence - 1725

premises.

G2 Contact number for incidents and responsible employees

- G2.1 The licensee must operate 24-hour telephone contact lines for the purpose of enabling the EPA to directly contact one or more representatives of the licensee who can:
- a) respond at all times to incidents relating to the premises; and
 - b) contact the licensee's senior employees or agents authorised at all times to:
 - i) speak on behalf of the licensee; and
 - ii) provide any information or document required under this licence.
- G2.2 The licensee is to inform the EPA in writing of the appointment of any contact persons, or changes to the person's contact details as soon as practicable and in any event within fourteen days of the appointment or change.

G3 Signage

- G3.1 The location of EPA point number(s) listed in tables P1.1, P1.2 & P1.3 must be clearly marked by signs that indicate the point identification number used in this licence and be located as close as practical to the point.

8 Pollution Studies and Reduction Programs

U1 Pollution Study 308: Dry weather overflow abatement program 2025-2029

- U1.1 **308.1** The objectives of this Pollution Study are to require the licensee to develop and submit a Sydney Water area of operations wide program of works for dry weather overflow (DWO) abatement in the 2025-2029 IPART price period which:
- a) targets reductions in both the frequency and volume of DWOs in areas where DWOs are likely to have a comparatively high environmental and/or human health impact; and
 - b) in the interests of attaining continuous improvement in sewage treatment system environmental performance, aims to achieve demonstrable improvement in the licensee's DWO environmental performance beyond its existing performance at 30 June 2025.
- U1.2 **308.2** The licensee must develop and submit in writing to the EPA by 2 December 2022 a report presenting a proposed Sydney Water area of operations wide program of works for DWO abatement in the 2025-2029 IPART price period which:
- a) targets reductions in both the frequency and volume of DWOs in areas where DWOs are likely to have a comparatively high environmental and/or human health impact, by prioritising works based on consideration of a range of factors, including but not needing to be limited to:
 - i. the likelihood of DWOs occurring.
 - ii. the likely volume of DWOs when they occur.
 - iii. the sensitivity, ecological value and public use of the receiving environment.
 - iv. the level of difficulty of access for response and clean-up of DWOs when they occur.
 - b) is based on consideration of a wide range of cost-effective contemporary, innovative and emerging DWO abatement methods, techniques and technologies with reference to Australian and international DWO

Environment Protection Licence

Licence - 1725

abatement best practice;

c) aims to achieve demonstrable improvement in the licensee's DWO environmental performance beyond its existing performance at 30 June 2025; and

d) includes:

i. a detailed description of the approach (including but not needing to be limited to an outline of the data, information and analyses) used to prioritise the areas selected for abatement based on condition 308.2a).

ii. a description of the program of works, including (but not needing to be limited to): a description of the types of works; the areas to be abated; and the scale/amount of works to be implemented.

iii. the rationale for the program of works, including (but not needing to be limited to) justification for the selection of: the types of works; the areas to be abated; and the scale/amount of works to be implemented.

iv. An estimated breakdown of the schedule of works for each financial year in the period 2025-2029.

v. the estimated costs of the works for each financial year in the period 2025-2029.

vi. an assessment of the expected benefits of the program of works in terms of (but not needing to be limited to) quantified estimated reductions in the frequency and volume of DWOs.

vii. (in line with condition 308.1b) a quantified assessment of how the program is expected to result in improved DWO environmental performance beyond the licensee's existing performance at 30 June 2025.

U1.3 308.3 The licensee must finalise the draft program of works by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such comments.

Note: A Pollution Reduction Program is intended to be included on the licence for implementation of dry weather overflow abatement works in 2025-2029 based on the outcomes of this Pollution Study.

U2 Pollution Study 309: Development of choke prioritisation methodologies to produce choke improvement prioritisation lists

U2.1 Pollution Study 309.1: Development of a choke prioritisation methodology for the purpose of producing a choke improvement prioritisation list - Improvement period 2025 - 2030

a) The objective of this Pollution Study is to require the Licensee to develop a choke prioritisation methodology, through the identification, development and use of appropriate tools and information, for use across all of the Licensees areas of operations in the choke improvement period 2025 – 2030.

b) The licensee must develop and submit in writing to the EPA by 30 June 2024 a draft choke prioritisation methodology which takes into account the likelihood and consequence of chokes occurring in a given area.

c) The licensee must finalise the draft choke prioritisation methodology by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such comments.

d) The licensee must host at least two progress workshops with the EPA throughout the development of the choke prioritisation methodology.

U2.2 Pollution Study 309.2: Refinement of the choke prioritisation methodology for the purpose of producing an improved choke improvement prioritisation list - Improvement period 2030 - 2035

Environment Protection Licence

Licence - 1725

- a) The objective of this Pollution Study is to require the Licensee to improve the choke prioritisation methodology developed under Pollution Study 309.1, through the identification, development and use of appropriate tools and information, for use across all of the Licensees areas of operations in the choke improvement period 2030 – 2035.
- b) The licensee must develop and submit in writing to the EPA by 30 June 2027 an improved choke prioritisation methodology which takes into account the likelihood and consequence of chokes occurring in a given area.
- c) The licensee must finalise the draft improved choke prioritisation methodology by addressing any written comments provided by the EPA and resubmit it to the EPA in writing within eight weeks of receiving such comments.
- d) Starting from the 2024-25 financial year, the licensee must host at least two progress workshops with the EPA throughout the development of the improved choke prioritisation methodology.

U3 PRP 308: Choke Improvement Pollution Reduction Program

U3.1 PRP 308.1: Choke Improvement Pollution Reduction Program – Improvement period 2025 - 2030

Note: The details of this PRP are to be determined following submission by the licensee of the choke improvement prioritisation list as required by condition L7.5a) before 31 December 2024.

U3.2 PRP 308.2: Choke Improvement Pollution Reduction Program – Improvement period 2030 - 2035

Note: The details of this PRP are to be determined following submission by the licensee of the choke improvement prioritisation list as required by condition L7.5a) before 31 December 2027.

9 Special Conditions

E1 Sydney Water Dry Weather Sewage Overflow Response Report

E1.1 Report Scope

a) The Licensee must provide a single, combined Report (“the Report”) on the adequacy of the systems, resources, processes, procedures, practices and training it has in place for its reticulation system as at the date which this condition is included in the Licence to comply with:

1. Condition O3.1 of the Sydney Water Environment Protection Licences (EPLs) on responding to sewer overflows; and
2. Part 5.7 of the Protection of Environment Operations Act 1997 (“the Act”) regarding the notification of incidents; and

Environment Protection Licence

Licence - 1725

3. Part 5.7A of the Act and Part 3A POEO (General) Regulation regarding requirements for a Pollution Incident Response Management Plan (PIRMP).

b) The Report is to identify any improvements that the Licensee should make so that its response to sewer overflows from its reticulation system complies with the regulatory requirements identified within this condition.

E1.2 Independent Expert

a) The Report must be prepared by a suitably qualified and experienced independent environmental expert (the "Expert").

b) Details of three options on the Expert (and team members) proposed to be engaged by the Licensee must be provided to the EPA's Regional Manager Operations - Metropolitan Infrastructure for written approval by 12 April 2019.

c) The Licensee must ensure when selecting the proposed Expert and their team for b) above that there is expertise in each team across all the areas of human health, aquatic and terrestrial ecology, water science, laboratory operations, sewage and environmental engineering, logistics and systems auditing. For the purposes of this condition, the Licensee must provide the EPA the following details for the Expert and each proposed team member:

1. name;
2. contact details;
3. the area in which they have expertise;
4. relevant qualifications;
5. relevant experience;
6. availability.

d) The Licensee must engage an Expert and team that is approved by the EPA's Regional Manager Operations - Metropolitan Infrastructure in writing by two weeks after approval is received from the EPA.

e) Once engaged, the Licensee must require the Expert and their team to meet with the EPA to discuss the background and context for the Report.

E1.3 Report Requirements

a) The Licensee must provide a single combined Report which examines, makes recommendations to improve and provides conclusions about the effectiveness of the licensee's procedures and processes with respect to its response to sewer overflows from its reticulation system.

b) The Report must detail the current systems, resources, processes, procedures, practices and training used by the Licensee on or around the time that this condition was included in this Licence.

c) The Licensee must also require the Expert to provide as part of the final Report:

1. a list of all the documents considered, including copies of any of the Licensee's procedures specifically referenced in the Report;
2. names, roles and organisations of personnel interviewed by the Expert (including their team members) in preparing the Report.

Environment Protection Licence

Licence - 1725

d) The report must consider the following:

E1.4 *Notifications*

- a. process for notification of incidents to the EPA to meet the requirements of Part 5.7 of the Act;
- b. process for determining incidents that trigger the statutory requirement for notification to the EPA per Part 5.7 of the Act;
- c. process for providing information to comply with Part 5.7 of the Act;
- d. process for providing further information to the EPA following the initial self-report in an accurate and timely manner to comply with Part 5.7 of the Act;
- e. the practices used to implement the processes under a – d in a timely and consistent manner;

E1.5 *Incident Management*

- f. roles and responsibilities of personnel involved in incident management including, but not limited to, overseeing of incident response, coordination and implementation of on ground response, liaison with and communication to the EPA, provision of information to the public, and whether roles and responsibilities are sufficiently clear;
- g. availability, accessibility and scheduling of suitable plant and personnel resources for all aspects of managing the sewer overflow;
- h. process and methodology used to allocate priority when responding to sewer overflows, including relationships to other responses being undertaken by the Licensee;
- i. whether the systems, resources, processes, procedures, practices and training in place for monitoring and auditing current processes require improvement and if so, the reasons, to meet the requirements of Condition O3.1 of the EPLs;

E1.6 *Rectification of faults and sewage containment*

- j. processes or procedures for response to, and rectification of, faults;
- k. adequacy of processes and procedures for achieving timely and satisfactory fault rectification;
- l. processes or procedures for implementation of sewage containment strategies;
- m. adequacy of processes and procedures for achieving timely implementation of sewage containment strategies;
- n. adequacy and effectiveness of the methods for, and execution of, sewage containment, to meet the requirements of Condition O3.1 of the EPLs;

E1.7 *Management of environmental and health impacts resulting from sewer overflows*

- o. assessment methodology for determining environmental and health impacts resulting from sewer overflows;
- p. assessment methodology for determining appropriate clean-up strategies to remediate the environment and reduce risk to public health;
- q. processes or procedures for achieving timely implementation of clean-up strategies;
- r. types of environmental remediation works utilised to clean-up after sewer overflows;
- s. effectiveness of environmental remediation works utilised to clean-up after sewer overflows;
- t. types of remediation works utilised for reducing public health risks from sewer overflows;
- u. effectiveness of remediation works utilised for reducing public health risks from sewer overflows;
- v. assessment methodology for determining the adequacy of clean-up strategies; and
- w. environmental impact of clean-up strategies, to meet the requirements of Condition O3.1 of the EPLs;

Environment Protection Licence

Licence - 1725

E1.8 *Risk communication*

- x. methods used to communicate potential health risks from sewer overflows to potentially affected parties to meet the requirements of Condition O3.1 of the EPLs. This may include but is not limited to signage, door knocking, written notification and physical barriers;
- y. processes for achieving timely implementation of communication referred to in (x) to meet the requirements of Condition O3.1 of the EPLs;
- z. adequacy and appropriateness of communication methods deployed; and

E1.9 *Training*

- aa. adequacy of the Licences' requirements for staff competency in relation to incident management, fault rectification, assessment of environmental and health risks and undertaking remediation works, including staff training provided by the Licensee.

E1.10 **Report**

- a) The Licensee must submit to the EPA's Regional Manager Operations - Metropolitan Infrastructure a draft Report ("Draft Report"), being a report prepared by the Expert (and their team) covering all of the matters described in conditions E1.3-E1.9, six months after the Expert is engaged (condition E1.2 d).
- b) The Licensee must ensure the Draft Report is updated to address any comments made by the EPA.
- c) The Licensee must submit to the EPA's Regional Manager Operations - Metropolitan Infrastructure the final Report one month after the EPA's comments have been provided (condition E1.10 b).

E1.11 **Implementation of the Report Recommendations**

- a) The Licensee must submit an Implementation Plan to the EPA's Regional Manager Operations - Metropolitan Infrastructure by no later than three months after acceptance of the final Report by the EPA (condition E1.10 c).
- b) The Implementation Plan must:
 1. identify what actions the Licensee proposes to take in response to the Report from the Expert;
 2. propose a timeframe for these action(s); and
 3. provide an explanation for the Licensee's proposals where there is any variance from the recommendations in the final Report.

- E1.12 a) The Licensee must complete all activities and outputs identified in Appendix 1 of the Implementation Plan dated 22 November 2020 by 30 June 2022.
- b) Evidence of the completion of the Implementation Plan activities and outputs must be provided to the EPA as outlined in Condition E1.13b.

E1.13 **Progress Report**

- a) The Licensee must submit a Progress Report to the EPA's Manager Regulatory Operations Metro every

Environment Protection Licence

Licence - 1725

three months from 25 October 2021 detailing the progress of all activities and outputs to be implemented in accordance with the Implementation Plan until all activities and outputs have been completed.

b) Each Progress Report outlined in condition E1.13a must:

1. Provide a status update on activities and outputs to achieve the recommendations identified in Appendix 1 of the Implementation Plan that have been completed since the last Progress Report; and
2. Outline any work packages that will not be completed by June 2022, including the details of any reasons why the Licensee has been unable to complete these work packages.

E2 Mandatory Environmental Audit

E2.1 Audit purpose

Subject to conditions E2.2 - E2.20 below, the licensee must engage an auditor to undertake a mandatory environmental audit ("the Audit"). The purpose of the Audit is to:

- a) provide information to the licensee about the adequacy of its systems to comply with regulatory requirements including compliance with the Act and licence conditions in order to:
 - prevent the occurrence of sewage overflows from rising mains and minimise the community and environmental health risks posed by these sewage overflows;
 - prevent the occurrence of sewage overflows from sewage pumping stations caused by failure and minimise the community and environmental health risks posed by these sewage overflows; and
- b) identify improvements to be made by the licensee so that the licensee's systems in place for managing sewage pumping stations and rising mains comply with the regulatory requirements including under the Act and licence conditions.

E2.2 Independent Auditor

The licensee must engage a suitably qualified and experienced independent certified environmental auditor (the "Auditor"). The Auditor may obtain the services of additional Auditor/s and relevant technical experts. At a minimum, the Auditor and team members must comprise of expertise in the areas of sewage and environmental engineering, logistics and systems auditing. It is noted that the EPA encourages the licensee to consider relevant international as well as national expertise. The Auditor and team members must be approved of in writing by the EPA before being engaged.

E2.3 By 2 December 2022, the licensee must provide the EPA by email addressed as "ATTENTION Manager ROMS" to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, with the details of at least three Auditors (and team members) that are suitably qualified to undertake the Audit under condition E2.6 - E2.14. The licensee may identify a preferred Auditor and team to undertake the Audit. For the purposes of this condition, the licensee must provide the EPA with the following details for the Auditor and each proposed team member:

- name;
- contact details;
- the area in which they have expertise;

Environment Protection Licence

Licence - 1725

- relevant qualifications;
- relevant experience; and
- availability.

E2.4 The EPA will approve an Auditor and team and advise the licensee in writing. The licensee must engage the approved Auditor team within two weeks after the EPA's approval.

E2.5 Within five weeks of engagement of the Auditor and team, the licensee must arrange for the Auditor and their team to meet with the EPA to discuss the background and context for the Audit.

Audit Scope

E2.6 The requirement to prepare an audit in relation to this licence can be satisfied by the licensee providing a single combined report that addresses issues relevant to each of the 23 licences the subject of these mandatory audit requirements.

E2.7 In relation to systems currently in place for managing and operating sewage pumping stations and rising mains, the Audit must:

- detail and examine those systems and the licensee's adherence to those systems;
- detail and examine any deficiencies in those systems and the licensee's adherence to those systems; and
- make recommendations and conclusions in respect of the following (E2.8 - E2.14), without limitation:

E2.8 *Construction and design*

a. systems for considering the following in the construction and design of new upgraded or replacement sewage pumping stations and rising mains:

- i. locational, environmental, and operational risk factors, including capacity of pumping stations and rising mains to account for future state planning needs;
- ii. future maintenance and resource requirements;
- iii. redundancy;

b. systems for ensuring the construction and design of new, upgraded or replacement sewage pumping stations and rising mains comply with relevant design and construction standards;

c. systems for ensuring quality control and quality assurance for new, upgraded or replacement sewage pumping stations and rising mains to comply with relevant standards;

d. adequacy of the systems in place for constructing and designing new, upgraded or replacement sewage pumping stations and rising mains including those at a.- c. to meet the regulatory requirements at condition E2.1.

e. adequacy of the systems in place for constructing and designing new, upgraded or replacement sewage pumping stations and rising mains including those at a.- c. to meet best international practice, codes of practice and relevant policies relating to the protection of the environment and human health.

E2.9 *Operation*

Environment Protection Licence

Licence - 1725

- f. the licensee's requirements for staff competency in relation to operating rising mains and pumping stations, including staff training by the licensee;
- g. adequacy of the systems for operating sewage pumping stations and rising mains in a manner which reduces risk factors related to failure, prevents the occurrence of sewage overflows and minimises the human health and environmental impact of resultant sewage overflows;
- h. adequacy of the systems for operating sewage pumping stations and rising mains to meet the regulatory requirements at condition E2.1;
- i. adequacy of the operating systems for sewage pumping stations and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment and human health.

E2.10 *Assessment of condition*

- j. systems for identifying the need to undertake condition assessment for sewage pumping stations and rising mains including methodology, timeliness, frequency, resource and financial allocation towards condition assessment and amongst different condition assessment activities;
- k. systems for planning and scheduling for short, medium and long term condition assessment for sewage pumping stations and rising mains including methodology, timeliness, frequency and, resource and financial allocation at the level of the officer staff overseeing condition assessment activities and at the business level of staff overseeing remedial activities, resource supply and, financial allocation;
- l. systems for undertaking condition assessment of rising mains and sewage pumping stations including methodology, timeliness, frequency and, resource and financial allocation;
- m. technology and techniques used to undertake condition assessment;
- n. systems to develop better technology and improved techniques to undertake condition assessment on sewage pumping stations and rising mains;
- o. systems for planning and undertaking of follow-up actions for sewage pumping stations and rising mains when condition assessment results are received, in particular what processes are followed when a condition assessment identifies recommendations, makes conclusions or proposes improvements or identifies that risk of failure factors have changed;
- p. systems for prioritising assessment of condition activities against both:
 - other rising main and sewage pumping station assets; and
 - other licensee plant systems and works;
- q. adequacy of the systems, technology and techniques including those at j.-p. for undertaking condition assessment for rising mains and pumping stations to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;
- r. adequacy of the systems, technology and techniques including those at j.-p. for undertaking condition assessment for rising mains and pumping stations to meet the regulatory requirements at condition E2.1.
- s. adequacy of the systems, technology and techniques at j.-p. for condition assessment of rising mains and pumping stations to meet best international practice, codes of practice and relevant policies relating to the protection of the environment.

E2.11 *Remedial activities*

- t. systems for identifying remedial activities needs including methodology, timeliness, frequency and, resource and financial allocation;
- u. systems for planning and scheduling for short, medium and long term remedial activities for sewage pumping stations and rising mains including methodology, timeliness, frequency and, resource allocation, at

Environment Protection Licence

Licence - 1725

the level of the officer staff overseeing remedial activities and at the business level of staff overseeing remedial activities, resource supply and, financial allocation;

v. systems for undertaking remedial activities including methodology, technology, timeliness, frequency and, resource and financial allocation;

w. technology and techniques used to undertake remedial activities for sewage pumping stations and rising mains;

x. systems to develop better technology and improved techniques to undertake remedial activities on sewage pumping stations and rising mains;

y. systems for considering all relevant risk factors related to failure of sewage pumping stations and rising mains in identifying and undertaking remedial activities;

z. systems for prioritising remedial activities for rising mains and sewage pumping stations against both:

- other rising main and sewage pumping station assets; and
- other licensee plant systems and works;

aa. systems for updating remedial schedules and plans when relevant and new or previously unaccounted for information is identified;

bb. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;

cc. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to meet the regulatory requirements at condition E2.1.

dd. the adequacy of systems for remedial activities for sewage pumping stations and rising mains including those at t.-aa. to meet best international practice, codes of practice and relevant policies relating to the protection of the environment.

E2.12 Contingency planning and response

ee. the systems for contingency planning and response to prevent a sewage overflow after failure occurs for sewage pumping stations and rising mains including:

i. the timeliness and availability of resources and information about contingency planning and response;

ii. the licensee's requirements for staff competency in relation to responding to failures of rising mains and pumping stations, including staff training by the licensee;

ff. after a sewage overflow occurs from a sewage pumping station or rising main, the systems for contingency planning and response to minimise the volume of sewage discharged to the environment and minimise environmental/human health impacts including:

i. the timeliness and availability of resources and information about contingency planning and response;

ii. the licensee's requirements for staff competency in relation to responding to failures of rising mains and sewage pumping stations, including staff training by the licensee;

gg. the systems for contingency planning before failure occurs in a sewage pumping station and rising main to:

- i. identify risk factors;
- ii. identify asset failure scenarios;
- iii. test and update plans;

hh. the adequacy of systems for contingency planning and response to prevent a sewage overflow after failure occurs for sewage pumping stations and rising mains to meet the regulatory requirements at condition E2.1;

ii. the adequacy of systems for contingency planning and response to minimise the volume of sewage discharged to the environment and minimise environmental/human health impacts after a sewage overflow

Environment Protection Licence

Licence - 1725

from a sewage pumping station or rising main occurs, to meet the regulatory requirements at condition E2.1;

- jj. the adequacy of systems for contingency planning before failure occurs in a sewage pumping station or rising main to meet the regulatory requirements at condition E2.1;
- kk. the adequacy of systems for contingency planning and response to prevent a sewage overflow after failure occurs in sewage pumping stations and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment;
- ll. the adequacy of systems for contingency planning and response to minimise the volume of sewage discharge to the environment and minimise environment and human health impacts after a sewage overflow occurs from a sewage pumping station and rising mains to meet best international practice, codes of practice and relevant policies relating to the protection of the environment
- mm. the adequacy of systems for contingency planning before failure occurs or issue arises in a sewage pumping station or rising main to meet best international practice, codes of practice and relevant policies relating to the protection of the environment.

E2.13 *Risk assessment and risk management*

- nn. the systems to undertake risk assessment/s including methodology, data sources and significance weightings given to components of the risk assessment to determine and manage the risk and consequence of failure;
- oo. the systems to review and update risk assessment/s including methodology, data sources, frequency and timeliness;
- pp. the systems for using risk assessment information for contingency planning
- qq. the systems for implementing action to mitigate risks;
- rr. the adequacy of the risk assessment systems including those at nn.-qq. to account for all relevant risk factors which could contribute to failure including (but not limited to) infrastructure characteristics, sewage characteristics, environmental conditions, locational, redundancy, accessibility and operational risk factors;
- ss. adequacy of risk assessment and risk management systems including those at nn.-qq. to reduce risk factors related to failure, prevent sewage overflows and minimise the human health and environmental impact of resultant sewage overflows;
- tt. adequacy of risk assessment and risk management systems including those at nn.-qq. for rising mains and sewage pumping stations to meet the regulatory requirements at condition E2.1;
- uu. the adequacy of risk assessment/s process to enable the licensee to prioritise and make decisions about rising main and sewage pumping station condition assessment and remedial activities.

E2.14 *Recommendations*

- vv. Recommendations for any improvements that the licensee should make so that its rising mains and pumping stations are operated and managed:
 - i. in accordance with best international practice and best available technology;
 - ii. in a manner which prevents future rising main and sewage pumping station failures and resultant sewage overflows;
 - iii. in a manner so that they are not carried on in an environmentally unsatisfactory manner;
 - iv. in order to meet the regulatory requirements at condition E2.1.
- ww. Recommendations for a broad strategic plan that the licensee should undertake for improvements made under vv., in time frames of less than 5 years, 10 years, 20 years and 30 years plus.

Environmental Audit Report Requirements

Environment Protection Licence

Licence - 1725

- E2.15 The licensee must instruct the Auditor to prepare a draft environmental audit report (“Draft Audit Report”), being a single, combined report prepared by the Auditor, which includes:
- a) all of the matters described in conditions E2.1, E2.6 and E2.7 - E2.14;
 - b) a list of documents considered and reviewed, including any of the licensee procedures specifically referenced in the Draft Audit Report;
 - c) names, roles and organisations of personnel interviewed by the Auditor (including their team members) in preparing the Draft Audit Report;
 - d) the two declarations required under Section 176 of the Act; and
 - e) a summary of the Audit including the conclusions and recommendations, in electronic format so it can be entered into the Public Register (as required by section 308 of the POEO Act).
- E2.16 The licensee must instruct the Auditor to provide the Draft Audit Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, within 6 months of the date of the EPA’s written approval of the Auditor and at the same time as, or before, the Draft Audit Report is provided to the licensee.
- E2.17 The licensee must ensure the Draft Audit Report is updated by the Auditor to address any comments made by the EPA.
- E2.18 The licensee must submit the Final Audit Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, no later than one month after receipt of the EPA’s comments on the Draft Audit Report. A PDF version of the report is to be provided.

Implementation of Recommendations of Mandatory Environmental Audit

- E2.19 The licensee must submit an Audit Implementation Report to the EPA by email addressed as “ATTENTION Manager ROMS” to info@epa.nsw.gov.au and copied to metrowater.infrastructure@epa.nsw.gov.au, by no later than 3 months after receipt of the Final Audit Report.
- E2.20 The Audit Implementation Report must:
- a) identify what actions the licensee proposes to take in response to the Audit Report;
 - b) propose a timeframe for these action(s); and
 - c) provide an explanation for the licensee’s proposals where there is any variance from the recommendations of the Auditor in the Final Auditor Report.

E2.21 Mandatory Environmental Audit Dictionary

For the purposes of conditions E2.1 to E2.20 the following definitions apply:

Rising main means:

a sewer pressure main which transfers sewage collected by sewage pumping station to a point of discharge such as a gravity sewer main or sewage treatment plant between the last valve inside a pumping station site



Environment Protection Licence

Licence - 1725

and the discharge point.

Sewage pumping station means:

a structure which controls the transport of sewage through the sewer pipes, where steep hills and other variations in the land topography can prevent or limit the gravity flow of sewage to the sewage treatment plant. The sewage pumping station includes infrastructure from the collecting manhole to the start of the rising main and all infrastructure relevant to the function of the sewage pumping station.

Environmentally unsatisfactory manner means:

the definition as specified in section 95 of the Act.

Systems means:

the licensee’s interacting or interdependent policies, plans, procedures, practices, processes, standards, strategies and resources (not limited to those) which are currently in place for managing and operating sewage pumping stations and rising mains.

Condition assessment means:

activities undertaken for the purpose of determining the condition of an asset. This includes (but is not limited to) activities undertaken to identify whether there are any leaks or defects on an asset, activities undertaken to determine how much life the asset has left, and activities to decide upon preventative maintenance or remedial work to extend its life or replacement of the asset.

Remedial activities means:

activities related to maintenance, repair, renewal, upgrade and redundancy upgrades.

Failure means:

an issue which inhibits or prevents normal operation of a sewage pumping station or rising main which could lead to sewage overflows.

E3 Special Dictionary

E3.1

Term	Definition
approved	Means approved in writing by the EPA. The EPA’s approval may be given unconditionally, or subject to conditions.
average concentration limit	Means the average of twelve monitoring test results undertaken during the reporting period.
average dry weather flow (ADWF)	Means the average flow at a point calculated or measured over a 24 hour period in dry weather.
Biosolids	Has the same meaning as in Schedule 1, Part 3 of the Protection of the Environment Operations Act 1997.
Biosolids Guidelines	Means the “Environmental Guidelines: Use and disposal of biosolids products” published by the EPA November 1997, or any subsequently updated guidelines which replace this publication.

Environment Protection Licence

Licence - 1725

Bypass	Means circumstances where sewage has been received at the sewage treatment plant but is discharged from the plant without it being treated, processed or reprocessed by means of any or all of the designed treatment processes of the plant. A new bypass event is defined as a bypass that commences at least 24 hours after the end of the previous bypass.
catchment	Catchment boundaries are marked on the system map.
cfu	Means colony forming units.
choke	Means a full or partial blockage in a sewer pipe that results in sewage being discharged to the environment. A choke may be caused by structural collapse of the sewer pipes, tree roots, debris or siltation.
condition	Means a condition of this licence.
directed overflow	Means a directed overflow structure within the reticulation system.
directed overflow structure	Means a designed structure (excluding access chambers) in the reticulation system which operates as a relief to allow sewage to discharge at a planned location or a sewage pumping station, but does not include a bypass from a sewage treatment plant.
dry weather	Dry weather occurs when less than 10 millimetres of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre
	of the catchment). Dry weather SPS discharge occurs when less than 10mm rainfall has been measured at a rain gauge in the catchment of the SPS during a 24 hour period (where there is no rain gauge in the catchment at the rain gauge closest to the SPS).
dry weather overflow	Means an overflow in the reticulation system not caused by wet weather, as determined by the hydraulic sewer system model.
effluent	Means sewage that has received all of the designed treatment processes at the sewage treatment plant.
emission factor	In relation to load-based licensing, means the level of emissions expected to be generated relative to another characteristic of the activity.
harm	Has the same meaning as in the Protection of the Environment Operations Act 1997.
kL	Means kilolitre.
L/s	Means litres per second.
leakage	Overflows caused by the exfiltration of sewage from faults, such as cracks, in sewer pipes to the surrounding environment.
licence issue date	Means the date of the issue of this licence, or if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.
mL	Means millilitres.
ML	Means megalitres.
node	Is a point in the hydraulic sewer system model that represents one or more overflows in the same catchment.
offensive odour	Has the same meaning as in the Protection of the Environment Operations Act 1997.

Environment Protection Licence

Licence - 1725

overflow	Is a discharge of untreated or partially treated sewage from the sewage treatment system. Overflows may occur as directed overflows or uncontrolled overflows.
Partial disinfection	Means a discharge of sewage or effluent from an STP that occurs when the flow rate of sewage at the influent point of the STP equals or exceeds the rate specified in condition O6.3.
Partial treatment discharge	Means a discharge of sewage or effluent from an STP that occurs when the flow rate of sewage at the influent point of the STP equals or exceeds the rate specified in condition O6.3 for Bondi, Malabar and North Head STPs only.
performance acceptance criteria	In relation to hydraulic sewer stem model, means the standard of accuracy (sometimes called the "goodness of fit") to be achieved when observations of a particular performance indicator are compared to the results predicted by the model.
reticulation system	Means that part of the sewage treatment system which collects and transports sewage to the sewage treatment plant and includes all sewer pipes (whether greater or less than 300mm diameter), access chambers, vent shafts, directed overflow structures and sewage pumping stations, but does not include the sewage treatment plant.
SCAMP	Sewer Catchment Asset Management Plan.
sewage	Means all material received in the reticulation system.
sewage products	Means any by-product of the treatment processes and includes biosolids, raw sludge, liquid sludge, thickened sludge, digested sludge, screenings and grit.
sewage pumping station (SPS)	Is a structure which controls the transport of sewage through the sewer pipes, where steep hills and other variations in the land topography can prevent or limit the gravity flow of sewage to the sewage treatment plant.
sewage treatment plant (STP)	Is a facility at which sewage is stored and treated following delivery from the reticulation system prior to discharge, and includes discharge structures and STP bypass points.
sewage treatment system	Means the reticulation system and the sewage treatment plant used for the transport, treatment and discharge of effluent and sewage.
sub-catchment	Sub-catchment boundaries are marked on the system map.
ten year rainfall time series data	Means the rainfall data for the period 1985 to 1994 as used in the EISs.
Trade waste agreements	Means agreements reached between the licensee and industrial and commercial customers to restrict the amount of toxic and other potentially harmful substances discharged to the sewerage system.
ug/L	Means micrograms per litre.
uncontrolled overflow	Means an overflow from any part of the reticulation system that is not a directed overflow. Leakage or overflows from access chambers are examples or uncontrolled overflows.
waters	Has the same meaning as in the Protection of the Environment Operations Act 1997.
waterways	Means the whole or any part of any river, stream, lake, lagoon, swamp, wetlands, natural or artificial watercourse, dam or tidal waters (including the sea), but does not include watercourses that are dry at the commencement of the overflow, or underground pipes, channels or gutters designed to receive or pass rainwater.

Environment Protection Licence



Licence - 1725

wet weather	Wet weather occurs when 10 millimetres or more of rainfall has been measured at a rain gauge in the catchment of the sewage treatment system during a 24 hour period (where there is no rain gauge in the catchment, at the rain gauge closest to the centre of the catchment).
wet weather overflow	Means an overflow in the reticulation system caused by wet weather as determined by the hydraulic sewer system model.



Environment Protection Licence

Licence - 1725

Dictionary

General Dictionary

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.
fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 2009.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997



Environment Protection Licence

Licence - 1725

flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
O&G	Means oil and grease
percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .



Environment Protection Licence

Licence - 1725

TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non-putrescible), special waste or hazardous waste
Wellhead	Has the same meaning as in Schedule 1 to the Protection of the Environment Operations (General) Regulation 2021.

Mr Warren Hicks

Environment Protection Authority

(By Delegation)

Date of this edition: 25-May-2000



Environment Protection Licence

Licence - 1725

End Notes	
1	Licence varied by notice V/M upgrade, issued on 06-Jul-2000, which came into effect on 06-Jul-2000.
2	Licence varied by notice 1005308, issued on 22-Oct-2001, which came into effect on 16-Nov-2001.
3	Licence varied by notice 1017893, issued on 27-Jun-2002, which came into effect on 28-Jun-2002.
4	Licence varied by notice 1018888, issued on 23-Dec-2002, which came into effect on 17-Jan-2003.
5	Licence varied by notice 1028459, issued on 08-Jul-2003, which came into effect on 02-Aug-2003.
6	Licence varied by notice 1032623, issued on 24-Nov-2003, which came into effect on 28-Nov-2003.
7	Licence varied by notice 1032929, issued on 22-Mar-2004, which came into effect on 02-Apr-2004.
8	Licence varied by notice 1048125, issued on 30-Jun-2005, which came into effect on 30-Jun-2005.
9	Licence varied by notice 1061406, issued on 29-Jun-2006, which came into effect on 29-Jun-2006.
10	Licence varied by notice 1074750, issued on 29-Jun-2007, which came into effect on 29-Jun-2007.
11	Licence varied by notice 1092449, issued on 05-Nov-2008, which came into effect on 05-Nov-2008.
12	Condition A1.3 Not applicable varied by notice issued on <issue date> which came into effect on <effective date>
13	Licence varied by admin corrections to annual return, issued on 02-Jul-2009, which came into effect on 02-Jul-2009.
14	Licence varied by notice 1116044, issued on 02-Jul-2010, which came into effect on 02-Jul-2010.
15	Licence varied by notice 1129015, issued on 27-Jun-2011, which came into effect on 27-Jun-2011.
16	Licence varied by notice 1504845 issued on 28-Jun-2012
17	Licence varied by notice 1513714 issued on 09-Jan-2014
18	Licence format updated on 17-Feb-2014
19	Licence varied by notice 1528919 issued on 23-Mar-2015
20	Licence varied by notice 1538173 issued on 19-Feb-2016



Environment Protection Licence

Licence - 1725

21	Licence varied by notice	1539410 issued on 14-Apr-2016
22	Licence varied by notice	1541424 issued on 23-Jun-2016
23	Licence varied by notice	1542263 issued on 06-Jul-2016
24	Licence varied by notice	1542678 issued on 22-Jul-2016
25	Licence varied by notice	1572470 issued on 30-Nov-2018
26	Licence varied by notice	1577318 issued on 25-Mar-2019
27	Licence varied by notice	1580169 issued on 01-Jul-2019
28	Licence varied by notice	1586323 issued on 04-Oct-2019
29	Licence varied by notice	1587648 issued on 31-Oct-2019
30	Licence varied by notice	1593920 issued on 16-Jun-2020
31	Licence varied by notice	1611939 issued on 27-Aug-2021
32	Licence varied by notice	1615263 issued on 16-Dec-2021
33	Licence varied by notice	1618981 issued on 03-Jun-2022
34	Licence varied by notice	1623855 issued on 27-Oct-2022
35	Licence varied by notice	1624311 issued on 30-Nov-2022
36	Licence varied by notice	1629208 issued on 26-Jun-2023
37	Licence varied by notice	1630837 issued on 28-Jul-2023
38	Licence varied by notice	1634962 issued on 25-Jan-2024